

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1700112 PWS NAME: CRESTLINE CITY PWS
PWS TYPE: Community SOURCE: Ground Water Sample Monitoring Point: EP001
STU ID: 1753657 STU NAME: CRESTLINE CITY

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Chemical Name (Code)	Monitoring Requirements	Sample Date
Consumer Confidence Report (CCR)		CCR is due July 1, 2007	
INORGANICS	ANTIMONY (1074) ARSENIC (1005) BARIUM (1010) BERYLLIUM (1075) CADMIUM (1015) CHROMIUM (1020) CYANIDE (1024) FLUORIDE (1025) MERCURY (1035) NICKEL (1036) SELENIUM (1045) THALLIUM (1085)	Not Required	
NITRATE	NITRATE (AS N) (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007	
NITRITE	NITRITE (AS N) (1041)	Not Required	
RADIOLOGICALS	GROSS ALPHA (4002) RADIUM 228 (4010)	Not Required	
VOLATILE ORGANIC CHEMICALS		Not Required	
SYNTHETIC ORGANIC CHEMICALS	ALACHLOR (LASSO) (2051) ATRAZINE (2050) SIMAZINE (2037)	Not Required	

2007 CHEMICAL MONITORING DISTRIBUTION POINT SCHEDULE

PWS ID: OH1700112 PWS Name: CRESTLINE CITY PWS
 PWS Type: Community Ground Water Population Served: 5088
 DISTRIBUTION ID: DS1 **Sample Monitoring Point: DS000**
 Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Monitoring Requirements	Sample Date
TOTAL CHLORINE (1000)	Sample in the distribution system *	
ASBESTOS (1094)	Not Required	
TOTAL HALOACETIC ACIDS (HAA5) (2456) TOTAL TRIHALOMETHANES (TTHM) (2950)	Not Required	
COPPER (1022) LEAD (1030)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use MR000 as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use RD000 as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Sarah Byerly of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Asbestos Sampling Information

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1732412 PWS NAME: EVANGELICAL NAZARETH LUTHERAN
STU ID: 1753679 STU NAME: EVANGELICAL NAZARETH LUTHERAN CHURCH
PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1735712 PWS NAME: GUS & MAGGIES

STU ID: 1753697 STU NAME: GUS & MAGGIES

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1736612 PWS NAME: RICHARDS LANDSCAPING

STU ID: 1753701 STU NAME: RICHARDS LANDSCAPING

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)

1 Sample(s) between 1/1/2007 to 5/31/2007

Sample Date: _____

NITRITE (1041)

Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1733912 PWS NAME: SUNSET SPRINGS CAMPGROUND-SOUTH WELL

STU ID: 1753686 STU NAME: SUNSET SPRING SOUTH WELL

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)

1 Sample(s) between 1/1/2007 to 5/31/2007

Sample Date: _____

NITRITE (1041)

Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1736912 PWS NAME: SUNSET SPRINGS CAMPGROUND-NORTH WELL

STU ID: 1753703 STU NAME: SUNSET SPRING NORTH WELL

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)

1 Sample(s) between 1/1/2007 to 5/31/2007

Sample Date: _____

NITRITE (1041)

Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1733612 PWS NAME: ST. PAUL LUTHERAN CHURCH - NORTH ROBINSO

STU ID: 1753683 STU NAME: SAINT PAULS LUTHERAN CHURCH

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1733812 PWS NAME: SULPHUR SPRINGS ELEMENTARY SCHOOL PWS

PWS TYPE: Community SOURCE: Ground Water Sample Monitoring Point: EP001

STU ID: 1753685 STU NAME: SULPHUR SPRINGS ELEM SCH

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Chemical Name (Code)	Monitoring Requirements	Sample Date
Consumer Confidence Report (CCR)		CCR is due July 1, 2007	
INORGANICS	ANTIMONY (1074) ARSENIC (1005) BARIUM (1010) BERYLLIUM (1075) CADMIUM (1015) CHROMIUM (1020) CYANIDE (1024) FLUORIDE (1025) MERCURY (1035) NICKEL (1036) SELENIUM (1045) THALLIUM (1085)	Not Required	
NITRATE	NITRATE (AS N) (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007	
NITRITE	NITRITE (AS N) (1041)	Not Required	
RADIOLOGICALS	GROSS ALPHA (4002) RADIUM 228 (4010)	Not Required	
VOLATILE ORGANIC CHEMICALS		Not Required	
SYNTHETIC ORGANIC CHEMICALS	ALACHLOR (LASSO) (2051) ATRAZINE (2050) SIMAZINE (2037)	Not Required	

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1734812 PWS NAME: WAGON WHEEL CAMPGROUND

STU ID: 1753690 STU NAME: WAGON WHEEL CAMPGROUND

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1735312 PWS NAME: WOODY RIDGE GOLF COURSE

STU ID: 1753695 STU NAME: WOODY RIDGE GOLF COURSE

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1700011 PWS NAME: BUCYRUS CITY PWS
PWS TYPE: Community SOURCE: Surface Water Sample Monitoring Point: EP001
STU ID: 1753656 STU NAME: BUCYRUS WTP
Effective Date: 2/14/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Chemical Name (Code)	Monitoring Requirements	Sample Date
Consumer Confidence Report (CCR)		CCR is due July 1, 2007	
INORGANICS	ANTIMONY (1074) ARSENIC (1005) BARIUM (1010) BERYLLIUM (1075) CADMIUM (1015) CHROMIUM (1020) CYANIDE (1024) FLUORIDE (1025) MERCURY (1035) NICKEL (1036) SELENIUM (1045) THALLIUM (1085)	1 Sample(s) between 1/1/2007 to 5/31/2007	
NITRATE	NITRATE (AS N) (1040)	1 Sample(s) Monthly	
NITRITE	NITRITE (AS N) (1041)	Not Required	
RADIOLOGICALS	GROSS ALPHA (4002) RADIUM 228 (4010)	Not Required	
TOTAL ORGANIC CARBON (TOC)	TOC (2920)	1 Paired Sample Set Monthly *	
VOLATILE ORGANIC CHEMICALS		1 Sample(s) between 1/1/2007 to 5/31/2007	
SYNTHETIC ORGANIC CHEMICALS	ALACHLOR (LASSO) (2051) ATRAZINE (2050) SIMAZINE (2037)	Test for each chemical per sample 1 sample between 5/1/2007 and 7/31/2007	

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2007 CHEMICAL MONITORING DISTRIBUTION POINT SCHEDULE

PWS ID: OH1700011 PWS Name: BUCYRUS CITY PWS
PWS Type: Community Surface Water Population Served: 13224
DISTRIBUTION ID: DS1 **Sample Monitoring Point: DS000**

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Monitoring Requirements	Sample Date
TOTAL CHLORINE (1000)	Sample in the distribution system *	
ASBESTOS (1094)	Not Required	
TOTAL HALOACETIC ACIDS (HAA5) (2456) TOTAL TRIHALOMETHANES (TTHM) (2950)	4 Sample(s) quarterly Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec	
COPPER (1022) LEAD (1030)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use MR000 as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use RD000 as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Sarah Byerly of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Asbestos Sampling Information

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1732512 PWS NAME: NEW WINCHESTER GOLF COURSE PWS

STU ID: 1753680 STU NAME: NEW WINCHESTER GOLF CRSE

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1734212 PWS NAME: TIRO TAVERN

STU ID: 1753688 STU NAME: TIRO TAVERN

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1734712 PWS NAME: VALLEY VIEW GOLF COURSE

STU ID: 1753689 STU NAME: VALLEY VIEW GOLF COURSE

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)

1 Sample(s) between 1/1/2007 to 5/31/2007

Sample Date: _____

NITRITE (1041)

Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1700411 PWS NAME: NEW WASHINGTON VILLAGE PWS
PWS TYPE: Community SOURCE: Surface Water Sample Monitoring Point: EP001
STU ID: 1753660 STU NAME: NEW WASHINGTON WTP
Effective Date: 2/14/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Chemical Name (Code)	Monitoring Requirements	Sample Date
Consumer Confidence Report (CCR)		CCR is due July 1, 2007	
INORGANICS	ANTIMONY (1074) ARSENIC (1005) BARIUM (1010) BERYLLIUM (1075) CADMIUM (1015) CHROMIUM (1020) CYANIDE (1024) FLUORIDE (1025) MERCURY (1035) NICKEL (1036) SELENIUM (1045) THALLIUM (1085)	1 Sample(s) between 1/1/2007 to 5/31/2007	
NITRATE	NITRATE (AS N) (1040)	1 Sample(s) Monthly	
NITRITE	NITRITE (AS N) (1041)	Not Required	
RADIOLOGICALS	GROSS ALPHA (4002) RADIUM 228 (4010)	Not Required	
TOTAL ORGANIC CARBON (TOC)	TOC (2920)	1 Paired Sample Set Monthly *	
VOLATILE ORGANIC CHEMICALS		1 Sample(s) between 1/1/2007 to 5/31/2007	
SYNTHETIC ORGANIC CHEMICALS	ALACHLOR (LASSO) (2051) ATRAZINE (2050) SIMAZINE (2037)	Test for each chemical per sample 1 sample between 2/1/2007 and 4/30/2007 1 sample in May 1 sample in June 1 sample in July 1 sample between 8/1/2007 and 10/31/2007 1 sample between 11/1/2007 and 12/31/2007	

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2007 CHEMICAL MONITORING DISTRIBUTION POINT SCHEDULE

PWS ID: OH1700411 PWS Name: NEW WASHINGTON VILLAGE PWS

PWS Type: Community Surface Water Population Served: 987

DISTRIBUTION ID: DS1 **Sample Monitoring Point: DS000**

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Monitoring Requirements	Sample Date
TOTAL CHLORINE (1000)	Sample in the distribution system *	
ASBESTOS (1094)	Not Required	
TOTAL HALOACETIC ACIDS (HAA5) (2456) TOTAL TRIHALOMETHANES (TTHM) (2950)	1 Sample(s) quarterly Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec	
COPPER (1022) LEAD (1030)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use MR000 as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use RD000 as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Sarah Byerly of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Asbestos Sampling Information

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1731012 PWS NAME: FOXFIRE FAMILY FUN PARK

STU ID: 1753673 STU NAME: FOXFIRE FAMILY FUN PARK

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1733712 PWS NAME: ST. PAUL LUTHERAN CHURCH - SULPHUR SPRIN

STU ID: 1753684 STU NAME: SAINT PAULS LUTHERAN CHURCH

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1700211 PWS NAME: GALION CITY PWS
PWS TYPE: Community SOURCE: Surface Water Sample Monitoring Point: EP001
STU ID: 1753658 STU NAME: GALION CITY
Effective Date: 2/14/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Chemical Name (Code)	Monitoring Requirements	Sample Date
Consumer Confidence Report (CCR)		CCR is due July 1, 2007	
INORGANICS	ANTIMONY (1074) ARSENIC (1005) BARIUM (1010) BERYLLIUM (1075) CADMIUM (1015) CHROMIUM (1020) CYANIDE (1024) FLUORIDE (1025) MERCURY (1035) NICKEL (1036) SELENIUM (1045) THALLIUM (1085)	1 Sample(s) between 1/1/2007 to 5/31/2007	
NITRATE	NITRATE (AS N) (1040)	1 Sample(s) Monthly	
NITRITE	NITRITE (AS N) (1041)	Not Required	
RADIOLOGICALS	GROSS ALPHA (4002) RADIUM 228 (4010)	Not Required	
TOTAL ORGANIC CARBON (TOC)	TOC (2920)	1 Paired Sample Set Monthly *	
VOLATILE ORGANIC CHEMICALS		1 Sample(s) between 4/1/2007 to 6/30/2007	
SYNTHETIC ORGANIC CHEMICALS	ALACHLOR (LASSO) (2051) ATRAZINE (2050) SIMAZINE (2037)	Test for each chemical per sample 1 sample in May 1 sample in June 1 sample in July	

* A paired sample set refers to one source water and one treated water sample. A source water alkalinity is also required at the same time the TOC sample is taken.

2007 CHEMICAL MONITORING DISTRIBUTION POINT SCHEDULE

PWS ID: OH1700211 PWS Name: GALION CITY PWS
PWS Type: Community Surface Water Population Served: 11341
DISTRIBUTION ID: DS1 **Sample Monitoring Point: DS000**
Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Monitoring Requirements	Sample Date
TOTAL CHLORINE (1000)	Sample in the distribution system *	
ASBESTOS (1094)	Not Required	
TOTAL HALOACETIC ACIDS (HAA5) (2456) TOTAL TRIHALOMETHANES (TTHM) (2950)	4 Sample(s) quarterly Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec	
COPPER (1022) LEAD (1030)	30 Sample(s) between 6/1/2007 to 9/30/2007	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use MR000 as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use RD000 as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Sarah Byerly of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Asbestos Sampling Information

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1730812 PWS NAME: CRAWFORD COUNTY CONSERVATION LEAGUE PWS

STU ID: 1753672 STU NAME: CRAWFORD COUNTY CONSERVATION LEAGUE

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1736412 PWS NAME: BU E COMP., INC

PWS TYPE: Nontransient Noncommunity SOURCE: Ground Water Sample Monitoring Point: EP001

STU ID: 1753700 STU NAME: BU E COMP INC

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	ANTIMONY (1074) ARSENIC (1005) BARIUM (1010) BERYLLIUM (1075) CADMIUM (1015) CHROMIUM (1020) CYANIDE (1024) FLUORIDE (1025) MERCURY (1035) NICKEL (1036) SELENIUM (1045) THALLIUM (1085)	Not Required	
NITRATE	NITRATE (AS N) (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007	
NITRITE	NITRITE (AS N) (1041)	Not Required	
VOLATILE ORGANIC CHEMICALS		Not Required	
SYNTHETIC ORGANIC CHEMICALS	ALACHLOR (LASSO) (2051) ATRAZINE (2050) SIMAZINE (2037)	Not Required	

2007 CHEMICAL MONITORING DISTRIBUTION POINT SCHEDULE

PWS ID: OH1700703 PWS Name: CRAWFORD COUNTY SEWER DISTRICT 2 PWS

PWS Type: Community Purchased Surface Water Population Served: 1277

DISTRIBUTION ID: DS1 **Sample Monitoring Point: DS000**

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Monitoring Requirements	Sample Date
TOTAL CHLORINE (1000)	Sample in the distribution system *	
TOTAL HALOACETIC ACIDS (HAA5) (2456) TOTAL TRIHALOMETHANES (TTHM) (2950)	1 Sample(s) quarterly Jan-Mar, Apr-Jun, Jul-Sep, Oct-Dec	
COPPER (1022) LEAD (1030)	Not Required	

Disinfectants and Disinfection Byproducts Sampling Information

TTHM and HAA5 sample(s) should be collected from point(s) in the distribution system where the water age is the oldest. Use MR000 as the sample monitoring point. If your system is also required to collect TTHM and HAA5 samples from other locations in your distribution system, use RD000 as the sample monitoring point. Any questions concerning this schedule or the Disinfectants and Disinfection Byproducts Rule can be directed to Sarah Byerly of the Ohio EPA DDAGW Central Office at (614) 644-2752. Your district office representative is also available to provide assistance.

Multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the number of TTHM and HAA5 samples required, with approval from Ohio EPA.

* Total chlorine samples are collected in the distribution system at the same time and place as total coliforms are sampled.

** One sample for Chlorite at each of the following locations: near the first customer, at a location representative of the average residence time, and at a location reflecting maximum residence time of the water in the distribution system.

Asbestos Sampling Information

Collect one sample at a tap served by asbestos-cement pipe. The sample monitoring point (smp) code is DS000. Due to limited Laboratory capacity and a 48 hour filtering requirement, contact your lab early in the monitoring period to schedule a sampling date.

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1730112 PWS NAME: BUCKEYE WEST ELEMENTARY SCHOOL

PWS TYPE: Nontransient Noncommunity SOURCE: Ground Water Sample Monitoring Point: EP001

STU ID: 1753666 STU NAME: BUCKEYE WEST ELEM SCL

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	ANTIMONY (1074) ARSENIC (1005) BARIUM (1010) BERYLLIUM (1075) CADMIUM (1015) CHROMIUM (1020) CYANIDE (1024) FLUORIDE (1025) MERCURY (1035) NICKEL (1036) SELENIUM (1045) THALLIUM (1085)	Not Required	
NITRATE	NITRATE (AS N) (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007	
NITRITE	NITRITE (AS N) (1041)	Not Required	
VOLATILE ORGANIC CHEMICALS		1 Sample(s) between 4/1/2007 to 6/30/2007	
SYNTHETIC ORGANIC CHEMICALS	ALACHLOR (LASSO) (2051) ATRAZINE (2050) SIMAZINE (2037)	Not Required	

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1700612 PWS NAME: SPRING VALLEY MOBILE HOME PARK
PWS TYPE: Community SOURCE: Ground Water Sample Monitoring Point: EP001
STU ID: 1753662 STU NAME: SPRING VALLEY MHP

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Chemical Name (Code)	Monitoring Requirements	Sample Date
Consumer Confidence Report (CCR)		CCR is due July 1, 2007	
INORGANICS	ANTIMONY (1074) ARSENIC (1005) BARIUM (1010) BERYLLIUM (1075) CADMIUM (1015) CHROMIUM (1020) CYANIDE (1024) FLUORIDE (1025) MERCURY (1035) NICKEL (1036) SELENIUM (1045) THALLIUM (1085)	Not Required	
NITRATE	NITRATE (AS N) (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007	
NITRITE	NITRITE (AS N) (1041)	Not Required	
RADIOLOGICALS	GROSS ALPHA (4002) RADIUM 228 (4010)	Not Required	
VOLATILE ORGANIC CHEMICALS		Not Required	
SYNTHETIC ORGANIC CHEMICALS	ALACHLOR (LASSO) (2051) ATRAZINE (2050) SIMAZINE (2037)	Not Required	

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1730012 PWS NAME: BUCKEYE EAST ELEMENTARY SCHOOL PWS
PWS TYPE: Nontransient Noncommunity SOURCE: Ground Water Sample Monitoring Point: EP001
STU ID: 1753665 STU NAME: BUCKEYE EAST ELEMENTARY SCHOOL
Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	ANTIMONY (1074) ARSENIC (1005) BARIUM (1010) BERYLLIUM (1075) CADMIUM (1015) CHROMIUM (1020) CYANIDE (1024) FLUORIDE (1025) MERCURY (1035) NICKEL (1036) SELENIUM (1045) THALLIUM (1085)	Not Required	
NITRATE	NITRATE (AS N) (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007	
NITRITE	NITRITE (AS N) (1041)	Not Required	
VOLATILE ORGANIC CHEMICALS		Not Required	
SYNTHETIC ORGANIC CHEMICALS	ALACHLOR (LASSO) (2051) ATRAZINE (2050) SIMAZINE (2037)	Not Required	

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1730712 PWS NAME: CRANBERRY HILLS GOLF COURSE

STU ID: 1753671 STU NAME: CRANBERRY HILLS GOLF COURSE

PWS TYPE: Transient Noncommunity Ground Water Sample Monitoring Point: EP001

Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact Northwest District Office - DDAGW at 419-352-8461 to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals (Code)

Monitoring Requirements

NITRATE (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007 Sample Date: _____
NITRITE (1041)	Not Required

2007 CHEMICAL MONITORING ENTRY POINT SCHEDULE

PWS ID: OH1732612 PWS NAME: ST. BERNARD SCHOOL AT NORTH AUBURN
PWS TYPE: Nontransient Noncommunity SOURCE: Ground Water Sample Monitoring Point: EP001
STU ID: 1753681 STU NAME: SAINT BERNARDS SCHOOL AT N AUBURN
Effective Date: 1/1/07

THIS SCHEDULE DOES NOT INCLUDE ALL MONITORING REQUIREMENTS FOR YOUR SYSTEM.

Contact your district office to review additional monitoring for coliform, monthly operating parameters, and/or other monitoring requirements not included on this schedule. For water emergencies that occur after hours, please call 800-282-9378

Chemicals	Chemical Name (Code)	Monitoring Requirements	Sample Date
INORGANICS	ANTIMONY (1074) ARSENIC (1005) BARIUM (1010) BERYLLIUM (1075) CADMIUM (1015) CHROMIUM (1020) CYANIDE (1024) FLUORIDE (1025) MERCURY (1035) NICKEL (1036) SELENIUM (1045) THALLIUM (1085)	Not Required	
NITRATE	NITRATE (AS N) (1040)	1 Sample(s) between 1/1/2007 to 5/31/2007	
NITRITE	NITRITE (AS N) (1041)	Not Required	
VOLATILE ORGANIC CHEMICALS		Not Required	
SYNTHETIC ORGANIC CHEMICALS	ALACHLOR (LASSO) (2051) ATRAZINE (2050) SIMAZINE (2037)	Not Required	

