



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 5, 2010

**Re: Harrison County
Tappan Lake Campground WWTP
Notice of Violation SNC
Permit OPX00016*BD
Correspondence (PWW)**

District Engineer
Muskingum Watershed Conservancy District
P.O. Box 349
New Philadelphia, Ohio 44663

Dear District Engineer:

We have received your self-monitoring reports covering the months of July through December 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
July 2009	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	8.18	7/1/2009
July 2009	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	8.18	7/1/2009
July 2009	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.3	1.26941	7/1/2009
July 2009	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.4	1.26941	7/1/2009
August 2009	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	24.3	8/1/2009
August 2009	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	24.3	8/1/2009
August 2009	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.3	3.771	8/1/2009
August 2009	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.4	3.771	8/1/2009
August 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.38	8/22/2009
October 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	5.36	10/21/2009
October 2009	001	50060	Chlorine, Total Residual	1D Conc	0.019	.21	10/27/2009
October 2009	001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	10/31/2009

- *NOTES:**
- 1D Conc = Daily Average Concentration Value (mg/l)
 - 1D Qty = Daily Average Loading Value (kg/day)
 - 7D Conc = Weekly Average Concentration Value (mg/l)
 - 30D Conc = Monthly Average Concentration Value (mg/l)
 - 7D Qty = Weekly Average Loading Value (kg/day)
 - 30D Qty = Monthly Average Loading Value (kg/day)

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have not already done so, please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5218.

Sincerely,



Dan Messerly
District Representative
Permits and Enforcement Section
Division of Surface Water

DM/dh