



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

October 9, 2009

**Re: Harrison County
Village of Cadiz WWTP
Notice of Violation SNC
Permit 0PB00009*DD
Correspondence (PWW)**

Mayor and Council
Village of Cadiz
128 Court Street
P.O. Box 153
Cadiz, Ohio 43907

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of April through June 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type	Units	Limit	Reported Value	Violation Date
May 2009:						
001	Total Suspended Solids	30D Conc	Mg/l	12	13.5	5/1/2009
001	Total Suspended Solids	30D Qty	Kg/d	27	27.9483	5/1/2009
001	Nitrogen, Ammonia (NH3)	30D Conc	Mg/l	4	5.605	5/1/2009
001	Nitrogen, Ammonia (NH3)	30D Qty		9.1	11.5259	5/1/2009
001	CBOD 5 day	30D Conc		10	15.625	5/1/2009
001	CBOD 5 day	30D Qty		23	32.7721	5/1/2009
001	pH	1D Conc		6.5	6.45	5/4/2009
001	CBOD 5 day	7D Qty		34	34.2830	5/8/2009
001	Nitrogen, Ammonia (NH3)	7D Conc		6	6.695	5/15/2009
001	Total Suspended Solids	7D Conc		18	35.	5/22/2009
001	Total Suspended Solids	7D Qty		41	69.9375	5/22/2009
001	Nitrogen, Ammonia (NH3)	7D Conc		6	9.64	5/22/2009
001	Nitrogen, Ammonia (NH3)	7D Qty		14	18.2942	5/22/2009
001	CBOD 5 day	7D Conc		15	41.	5/22/2009
001	CBOD 5 day	7D Qty		34	77.8911	5/22/2009
June 2009:						
001	Total Suspended Solids	30D Conc	Mg/l	12	17.4444	6/1/2009
001	Total Suspended Solids	7D Conc	Mg/l	18	23.	6/1/2009

Outfall	Parameter	Type	Units	Limit	Reported Value	Violation Date
001	Total Suspended Solids	30D Qty	Kg/day	27	29.2476	6/1/2009
001	Nitrogen, Ammonia (NH3)	30D Conc		4	4.27244	6/1/2009
001	Nitrogen, Ammonia (NH3)	7D Conc		6	7.23	6/1/2009
001	CBOD 5 day	30D Conc		10	14.3333	6/1/2009
001	CBOD 5 day	7D Conc		15	20.5	6/1/2009
001	CBOD 5 day	30D Qty		23	24.5245	6/1/2009
001	CBOD 5 day	7D Qty		34	38.5528	6/1/2009
001	Nitrogen, Ammonia (NH3)	7D Conc		6	6.015	6/8/2009
001	Total Suspended Solids	7D Conc		18	20.	6/15/2009
001	Total Suspended Solids	7D Conc		18	21.	6/22/2009
001	CBOD 5 day	7D Conc		15	22.	6/22/2009

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have not already done so, please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5218.

Sincerely,



Dan Messerly
District Representative
Permits and Enforcement Section
Division of Surface Water

DM/dh