



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 14, 2009

Re: Hocking County
Old Man's Cave Chalets
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PR00114*BD
Correspondence (PWW)

Mr. Mark Devol, Owner
Old Man's Cave Chalets
18905 State Route 664
Logan, Ohio 43138

Dear Mr. Devol:

We have reviewed your self-monitoring reports covering the months of October through December 2008 for the Old Man's Cave Chalets Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Qty	0.11	.12112	7/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1	15.	7/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.01	.18168	7/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	15.	7/22/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.014	.18168	7/22/2008
001	00300	Dissolved Oxygen	1D Conc	6	3.4	8/7/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.46	9/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	20.4	10/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0094	.23164	10/1/2008
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	20.4	10/23/2008
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.0142	.23164	10/23/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	15.	11/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.0284	.04542	11/1/2008
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	4.5	15.	11/19/2008
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.0426	.04542	11/19/2008

* 7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within 10 days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/mlm

c: Rick Verhotz, Stantec