



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

November 30, 2007

Re: Jackson County
Aluchem of Jackson, Inc.
Self-monitoring Report Violations
Ohio EPA Permit 0IN00068*DD
Correspondence (IWW)

Mr. Chad Bahay
Aluchem of Jackson
14782 Beaver Pike
Jackson, Ohio 45640

Dear Mr. Bahay:

We have received your self-monitoring reports covering the months of April through September 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type	Units	Permit Limit	Reported	Date
April 2007:						
001	CBOD 5 day	30D Conc	mg/L	10	334.	4/1/2007
001	Total Suspended Solids	30D Conc	mg/L	12	28.5	4/1/2007
001	CBOD 5 day	1D Conc	mg/L	15	334.	4/20/2007
001	Total Suspended Solids	1D Conc	mg/L	18	28.5	4/20/2007
May 2007:						
002	Total Suspended Solids	30D Conc	mg/L	40	56.	5/1/2007
002	Total Suspended Solids	1D Conc	mg/L	50	56.	5/29/2007
September 2007:						
001	Chlorine, Total Residual	1D Conc	mg/L	0.038	.2	9/13/2007

- *NOTES:** 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Also, Aluchem has failed to report odor, color and turbidity daily at outfall 001 for most of January-September 2007; and has failed to report flow rate daily at outfall 001 and when discharging at outfall 002 for January through September 2007.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions, please contact me at (740) 380-5284 at your convenience.

Sincerely,

A handwritten signature in black ink, appearing to read "Abbot Stevenson", with a long horizontal flourish extending to the right.

Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh