



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 5, 2010

Re: Jackson County
Wellston PWS South Plant
Notice of Violation SNC
Permit OIY00081*AD
Correspondence (IWW)

Mayor and Council
Village of Wellston
203 East Broadway
Wellston, Ohio 45692

Dear Mayor & Council:

We have received your self-monitoring report covering the months of July through November 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
November 2009	001	01044	Iron, Suspended (Fe)	30D Conc	1000	1470.	11/1/2009
November 2009	001	01044	Iron, Suspended (Fe)	1D Conc	2000	2160.	11/24/2009

- NOTES:**
- 1D Conc = Daily Average Concentration Value
 - 1D Qty = Daily Average Loading Value
 - 7D Conc = Weekly Average Concentration Value
 - 30D Conc = Monthly Average Concentration Value
 - 7D Qty = Weekly Average Loading Value
 - 30D Qty = Monthly Average Loading Value

In addition, we have not received your renewal application for this NPDES permit, as required. Please submit the application at once.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have not already done so, please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5218.

Sincerely,

A handwritten signature in cursive script, appearing to read "Dan Messerly".

Dan Messerly
District Representative
Permits and Enforcement Section
Division of Surface Water

DM/dh