



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 9, 2009

**Re:** Jackson County  
Wellston PWS South Plant  
Notice of Violation SNC  
Permit 0IY00081\*AD  
Correspondence (PWW)

Mayor and Council  
Village of Wellston  
203 East Broadway  
Wellston, Ohio 45692

Dear Commissioners:

We have received your self-monitoring report covering the months of April through June 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2009	001	Chlorine, Total Residual	1D Conc	0.019	.07	5/14/2009
June 2009	001	Chlorine, Total Residual	1D Conc	0.019	.06	6/25/2009

In addition, the following frequency violations were noted:

Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
<b>June 2009:</b>					
001	Flow Rate	1/Day	1	0	06/12/2009
001	Flow Rate	1/Day	1	0	06/13/2009
001	Flow Rate	1/Day	1	0	06/14/2009
001	Flow Rate	1/Day	1	0	06/15/2009
001	Flow Rate	1/Day	1	0	06/21/2009

**NOTES:** 1D Conc = Daily Average Concentration Value  
 1D Qty = Daily Average Loading Value  
 7D Conc = Weekly Average Concentration Value  
 30D Conc = Monthly Average Concentration Value  
 7D Qty = Weekly Average Loading Value  
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have not already done so, please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5218.

Sincerely,



Dan Messerly  
District Representative  
Permits and Enforcement Section  
Division of Surface Water

DM/dh