



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 30, 2009

**Re: Washington County
Village of Beverly
Self-Monitoring Report Violations
Ohio EPA Permit No. OPB000002*GD
NPDES Permit No. OH0020648
Correspondence (PWW)**

Mayor and Council
Village of Beverly
919 Mitchell Avenue
Beverly, Ohio 45715

Dear Mayor and Council:

We have received your self-monitoring report covering the months of July through October 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Total Suspended Solids	30D Conc	30	33.5	7/1/2008
001	Total Suspended Solids	7D Conc	45	55.5	7/15/2008
001	Fecal Coliform	30D Conc	1000	2947.88	7/1/2008
001	Fecal Coliform	7D Conc	2000	2947.88	7/1/2008
001	CBOD 5 day	30D Conc	25	37.75	7/1/2008
001	CBOD 5 day	7D Conc	40	112.5	7/22/2008
001	CBOD 5 day	7D Qty	45.5	71.8941	7/22/2008
001	Total Suspended Solids	7D Conc	45	75.	9/22/2008
001	Total Suspended Solids	30D Qty	34.1	36.3808	10/1/2008
001	Total Suspended Solids	7D Conc	45	99.5	10/1/2008
001	Total Suspended Solids	30D Conc	30	67.2857	10/1/2008
001	Total Suspended Solids	7D Qty	51.2	56.5838	10/15/2008
001	Total Suspended Solids	7D Conc	45	98.	10/15/2008
001	Fecal Coliform	7D Conc	2000	2000.	8/1/2008
001	Fecal Coliform	30D Conc	1000	1196.27	8/1/2008
001	Fecal Coliform	7D Conc	2000	6400.	8/8/2008
001	Fecal Coliform	30D Conc	1000	1600.	9/1/2008
001	Fecal Coliform	7D Conc	2000	3200.	9/1/2008
001	Fecal Coliform	30D Conc	1000	3700.	10/1/2008
001	Fecal Coliform	7D Conc	2000	3700.	10/22/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U.S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (740) 380-5434.

Sincerely,



Stephen Wells
District Representative
Division of Surface Water

SW/dh

c: Kevin Torrence, Operator, Village of Beverly