



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

September 20, 2011

Re: Washington County
Village of Beverly
Compliance Evaluation Inspection
Correspondence (PWW)

Mr. Dave Combs, President
Board of Public Affairs
Village of Beverly
919 Mitchell Avenue
Beverly, Ohio 45715

Dear Mr. Ullman:

On July 27, 2011, a Compliance Evaluation Inspection (CEI) was conducted at the Village of Beverly's wastewater treatment plant. The purpose of the inspection was to determine Beverly's compliance with its National Pollutant Discharge Elimination System (NPDES) Permit. Present for the inspection were Sam Booker and Bryan Jarvis, representing Beverly and Stephen Wells representing Ohio EPA, Division of Surface Water, Southeast District Office. No wastewater samples were collected as part of the inspection. A copy of my inspection report is attached.

As a result of my inspection, I have the following comments:

1. The Village has been working on removing inflow/infiltration (I/I) from its collection system. The Village is planning on doing additional smoke testing and televising of the collection system. Please update this office on the status of the I/I removal.
2. Since the last inspection, the wastewater treatment plant has completed the upgrades. The upgrades included the addition of an effluent flow meter, sludge press and UV disinfection.
3. One of the pumps in the deep well is scheduled to be replaced as part of the regular operation and maintenance at the wastewater treatment plant. The Village needs to continue planning and budgeting for regular operation and maintenance at the wastewater treatment plant.

4. A discussion on the general lab inspection was done as part of the inspection. A copy of the lab inspection checklist is attached. As a result of the discussion, the wastewater treatment plant was performing the analytical test correctly, however, additional documentation will be necessary. Please review the attached checklist and implement any documentation that is required.

In conclusion, the Village of Beverly appeared to be in compliance with its NPDES Permit at the time of the inspection.

Please respond to the Comment #1 in writing to this office within 20 days of receipt of this letter.

If you have any questions, feel free to contact me at (740) 380-5434.

Sincerely,



Stephen Wells
District Representative
Division of Surface Water

SW/dh

Enclosure

c: Bryan Jarvis, Operator

NPDES Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PB00002*HD	OH0020648	July 27, 2011	C	S	1

B. FACILITY DATA

Name & Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Beverly Wastewater Treatment Plant 522 State Route 60 Beverly, OH	9:45 a.m.	August 1, 2008
	Exit Time	Permit Expiration Date
	11:50 a.m.	July 31, 2013

Name(s) & Title(s) of On-Site Representative(s)	Phone Number(s)
Bryan Jarvis, Operator	(740) 984-1052
Name, Address, & Title of Responsible Official	Phone Number
Dave Combs, President Village of Beverly Board of Public Affairs 919 Mitchell Avenue Beverly, OH 45715	(740) 984-1052

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u>--</u> Other
<u>M</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated; N/A = Not Applicable)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.



 Stephen Wells, Inspector, Ohio EPA, Southeast District Office

9/20/11

 Date



 Jennifer M. Witte, Reviewer, Ohio EPA, Southeast District Office

9/20/11

 Date