



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 27, 2008

Re: Meigs County
Pomeroy WWTP
Self-Monitoring Report Violations
NPDES Permit No. 0PB00032*GD
Correspondence (PWW)

Mayor and Council
Village of Pomeroy
320 East Main Street
Pomeroy, Ohio 45769

Dear Mayor and Council:

We have received your self-monitoring report covering the months of October 2007 through March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
October 2007:						
001	50060	Chlorine, Total Residual	1D Conc	0.038	.13	10/19/2007
001	50060	Chlorine, Total Residual	1D Conc	0.038	.3	10/22/2007
001	50060	Chlorine, Total Residual	1D Conc	0.038	.19	10/23/2007
001	50060	Chlorine, Total Residual	1D Conc	0.038	.11	10/24/2007
001	50060	Chlorine, Total Residual	1D Conc	0.038	.13	10/25/2007
001	50060	Chlorine, Total Residual	1D Conc	0.038	.05	10/26/2007
November 2007:						
001	50060	Chlorine, Total Residual	1D Conc	0.038	.09	11/29/2007
001	50060	Chlorine, Total Residual	1D Conc	0.038	.05	11/30/2007
December 2007:						
001	50060	Chlorine, Total Residual	1D Conc	0.038	.05	12/13/2007
January 2008:						
001	50060	Chlorine, Total Residual	1D Conc	0.038	.1	1/15/2008
001	50060	Chlorine, Total Residual	1D Conc	0.038	.11	1/16/2008
001	50060	Chlorine, Total Residual	1D Conc	0.038	.09	1/17/2008
February 2008:						
001	50060	Chlorine, Total Residual	1D Conc	0.038	.08	2/11/2008
001	50060	Chlorine, Total Residual	1D Conc	0.038	.05	2/12/2008
001	50060	Chlorine, Total Residual	1D Conc	0.038	.09	2/13/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5447.

Sincerely,



Mike Yandrich
District Representative
Division of Surface Water

MY/dh