



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6480
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 8, 2010

Re: Lawrence County
Deering Elementary
Inspection
Correspondence (PWW)

Mr. Dennis DeCamp, Superintendent
Dawson-Bryant Schools
122 Lane Street
Coal Grove, Ohio 45638

Dear Mr. DeCamp:

On June 23, 2010, I conducted an inspection at Dawson Bryant's Deering Elementary School. The purpose of the inspection was to determine Dawson Bryant's compliance with its National Pollutant Discharge Elimination System (NPDES) Permit. A copy of inspection report is attached.

One issue was observed during the inspection. One of the sand filters had a large amount of weeds and grass. The other bed was clean and appeared to be the one in use. The other bed needs to be cleaned out. Please inform this office when the other sand filter is cleaned.

In conclusion, Dawson Bryant Schools appeared to be in compliance with its NPDES Permit at the time of the inspection.

If you have any questions, feel free to contact me at (740) 380-5434.

Sincerely,

Stephen Wells
District Representative
Division of Surface Water

SW/dh

Enclosure