



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 9, 2007

Re: Muskingum County
Village of Frazeytsburg
Reconnaissance Inspection
Correspondence(PWW)

Mr. Eric Householder
P.O. Box 160
Frazeytsburg, Ohio 43822

Dear Mr. Householder:

On July 19, 2007, Tim Campbell of Ohio EPA Southeast District DSW, and I conducted a Reconnaissance Compliance Inspection for the Village of Frazeytsburg WWTP. We spoke with the operator, Mr. Keith Chaney. The following are comments from the inspection:

The sludge rake was broken and was not functioning at the time of the inspection. Please repair this ASAP. This is a recurring problem and the equipment should be provided regular maintenance.

The weirs on the clarifier need regular scheduled cleaning. Weeds and other debris were growing on the tank walls and the weirs have sludge deposits on them.

The revisions for the plant upgrade PTI have not been received, but Mr. John Groves contacted our office and said a letter explaining the revisions should be received shortly.

Please respond to this letter by August 30, 2007.

Sincerely,

Scott Foster
Environmental Specialist 2
Division of Surface Water

SF/dh

Enclosure

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PB00015*FD	OH0020800	July 19, 2007	R	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Frazeytsburg WWTP County Road 8 Frazeytsburg, Ohio 43822	9:00 AM	April 1, 2006
	Exit Time	Permit Expiration Date
	9:30 AM	March 31, 2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Keith Chaney, Operator	740-828-2240
Name, Address and Title of Responsible Official	Phone Number
Eric Householder, Village Administrator PO Box 160 Frazeytsburg, Ohio 43822	740-828-2240

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N</u> Pretreatment
<u>S</u> Records/Reports	<u>N</u> Laboratory	<u>N</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>M</u> Sludge Storage/Disposal	<u>--</u> Other
<u>N</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See Attached Letter.



Scott Foster, Inspector, Ohio EPA, Southeast District Office

8/9/07

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

8/9/07

Date