



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 3, 2009, 2009

Re: Noble County
BP Bulk Plant - Caldwell
Compliance Evaluation Inspection
Correspondence (IWW)

Mr. Frank Marsek
BP Oil Company
4850 East 49th Street
Cuyahoga Heights, Ohio 44125

Dear Mr. Marsek:

On July 14, 2009, I conducted a compliance evaluation inspection (CEI) at the Caldwell BP Bulk Plant facility operated by Mr. Richard Rutherford. The purpose of the inspection was to determine compliance status with the terms and conditions of National Pollutant Discharge Elimination System (NPDES) permit number 01N00227*CD. Mr. Richard Rutherford, owner of the Caldwell BP business, was present at the time of my inspection.

Based on the findings of my inspection and the review of our records, I have the following comments:

1. At the time of my inspection, the dike containment area was structurally sound and the small lined detention pond receiving discharge from the oil water separator was clean with no visible sheen. During my inspection, the water level in the pond was low and no discharge was observed.
2. During my inspection, it was discussed with Mr. Rutherford that any surface runoff should be diverted away from the bulk fuel loading area. The current grading of the driveway area up-gradient of the spill containment pad allows surface water to drain directly into the catch basin, which discharges, to the oil water separator. It was instructed to Mr. Rutherford that a simple water diversion should be graded into the gravel drive to minimize the drainage of clean water into the catch basin.

Attached is a copy of my detailed inspection report. If you have any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JGG/jg

Enclosure

c: Richard Rutherford, Business Owner of Caldwell BP

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0IN00227*CD	OH0124583	July 14, 2009	C	S	2

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
BP Bulk Plant- Caldwell Facility Miller Street Caldwell, Ohio	8:00 a.m.	May 1, 2007
	Exit Time	Permit Expiration Date
	8:45 a.m.	April 30, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Richard Rutherford, Business Owner	
Name, Address and Title of Responsible Official	Phone Number
Mr. Frank Marsek BP Oil Company 4850 East 49 th Street Cuyahoga Heights, Ohio 44125	

C. AREAS EVALUATED DURING INSPECTION

<u> </u> S Permit	<u> </u> S Flow Measurement	<u> </u> N/A Pretreatment
<u> </u> S Records/Reports	<u> </u> * Laboratory	<u> </u> N/A Compliance Schedules
<u> </u> S Operations & Maintenance	<u> </u> * Effluent/Receiving Waters	<u> </u> S Self-Monitoring Program
<u> </u> S Facility Site Review	<u> </u> N/A Sludge Storage/Disposal	<u> </u> Other
<u> </u> N/A Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

* Contract Laboratory used and not evaluated. No discharge was observed. See attached letter.

Jake Greuey
Jake Greuey, Inspector, Ohio EPA, Southeast District Office

8/14/09
Date

Timothy M. Campbell
Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

8/14/09
Date