



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 28, 2010

**Re: Adams County
DP&L Killen
Self-Monitoring Report Violations
Ohio EPA Permit No. 01B00022
Correspondence (PWW)**

Mr. Michael Harrell, Plant Manager
DP&L Killen
14869 US 52
Manchester, Ohio 45144

Dear Mr. Harrell:

We have received your self-monitoring report covering the months of July through December 2009 for your wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00550	Oil and Grease, Total	1D Conc	8.2	9.53	10/6/2009
001	00550	Oil and Grease, Total	1D Conc	8.2	8.54	11/10/2009

Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported	Violation Date
001	00530	Total Suspended Solids	1/Week	1	0	09/08/2009
001	50060	Chlorine, Total Residual	1/Week	1	0	09/15/2009
001	00400	pH	1/Week	1	0	09/08/2009
001	00550	Oil and Grease, Total	1/Week	1	0	09/08/2009
001	00940	Chloride, Total	1/Week	1	0	09/08/2009
001	00515	Residue, Total Dissolved	1/Week	1	0	09/08/2009

- * 1D Qty is equal to a maximum daily loading limit.
- 1D Conc is equal to the maximum daily concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Within 10 days from receipt of this letter submit a letter to this office outlining the reasons for the above permit violations and actions being taken to prevent further occurrences. No action is required if you have already submitted documentation outlining the causes of these violations and corresponding corrective actions.

If there are any questions, please contact me at (740) 380-5277.

Sincerely,



Aaron Wolfe
Storm Water Coordinator
Division of Surface Water

AW/dh

c: Jim Stice