



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 13, 2009

Re: Adams County
DP&L Killen
Self-Monitoring Report Violations
Ohio EPA Permit No. 0IB00022
Correspondence (PWW)

Mr. Michael Harrell, Plant Manager
14869 US 52
Manchester, Ohio 45144

Dear Mr. Harrell:

We have received your self-monitoring report covering the months of April 2009 through June 2009 for your wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Violation Date	Station	Reporting Code	Parameter	Sample Frequency	Reported
April 2009	4/1/2009	001	50060	Chlorine, Total Residual	1/Week	0
April 2009	4/1/2009	001	00550	Oil and Grease, Total	1/Week	0
April 2009	4/1/2009	001	00940	Chloride, Total	1/Week	0
April 2009	4/1/2009	001	00515	Residue, Total Dissolv	1/Week	0

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2009	001	Chromium, Dissolved He	1D Conc	31	74.4	5/5/2009
May 2009	001	Chromium, Dissolved He	1D Qty	1.34	2.02755	5/5/2009


- * 1D Qty is equal to a maximum daily loading limit.
- 1D Conc is equal to the maximum daily concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Within 10 days from receipt of this letter submit a letter to this office outlining the reasons for the above permit violations and actions being taken to prevent further occurrences. No action is required if you have already submitted documentation outlining the causes of these violations and corresponding corrective actions.

If there are any questions, please contact me at (740) 380-5277.

Sincerely,



Aaron Wolfe
Storm Water Coordinator
Division of Surface Water

AW/dh

c: Jim Stice