



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 28, 2010

**Re:** Adams County  
Locust Grove MHP  
Self-Monitoring Report Violations  
Ohio EPA Permit No. OGS00022  
Correspondence (PWW)

Mr. George Thompson  
Locust Grove Mobile Home Park  
254 O'Connor Road  
Lucasville, Ohio 45648

Dear Mr. Thompson:

We have received your self-monitoring reports covering the months of July through December 2009 for your wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	.1	9/18/2009

- \* 1D Qty is equal to a maximum daily loading limit.
- 1D Conc is equal to the maximum daily concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Within 10 days from receipt of this letter submit a letter to this office outlining the reasons for the above permit violations and actions being taken to prevent further occurrences. No action is required if you have already submitted documentation outlining the causes of these violations and corresponding corrective actions.

If there are any questions, please contact me at (740) 380-5277.

Sincerely,

Aaron Wolfe  
Storm Water Coordinator  
Division of Surface Water

AW/dh