



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 10, 2009

Re: Adams County
Murphin Ridge
Self-Monitoring Report Violations
Ohio EPA Permit No. OPR00091
Correspondence (PWW)

Mr. Darryl McKenny
Murphin Ridge Inn
750 Murphin Ridge Road
West Union, Ohio 45693

Dear Mr. McKenny :

We have received your self-monitoring report covering the months of September 2008 through March 2009 for your wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	2.2	9/10/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	1.01	9/25/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	2.2	10/9/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	1.8	10/23/2008
001	00530	Total Suspended Solids	30D Conc	12	13.	3/1/2009
001	80082	CBOD 5 day	30D Conc	10	11.	3/1/2009

- * 1D Qty is equal to a maximum daily loading limit.
- 1D Conc is equal to the maximum daily concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Within 10 days from receipt of this letter submit a letter to this office outlining the reasons for the above permit violations and actions being taken to prevent further occurrences. No action is required if you have already submitted documentation outlining the causes of these violations and corresponding corrective actions.

If there are any questions, please contact me at (740) 380-5277.

Sincerely,

A handwritten signature in black ink, appearing to read 'Aaron Wolfe', written over a horizontal line.

Aaron Wolfe
Storm Water Coordinator
Division of Surface Water

AW/dh