



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

January 28, 2010

Re: Adams County
Village of Seaman
Self-Monitoring Report Violations
Ohio EPA Permit No. OPB00098
Correspondence (PWW)

Mayor and Council
Village of Seaman
17806 State Route 247
P.O. Box 248
Seaman, Ohio 45679

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of July through December 2009 for your wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	7D Conc	2000	2600.	7/1/2009
001	31616	Fecal Coliform	7D Conc	2000	7600.	8/15/2009

- * 1D Qty is equal to a maximum daily loading limit.
- 1D Conc is equal to the maximum daily concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Within 10 days from receipt of this letter submit a letter to this office outlining the reasons for the above permit violations and actions being taken to prevent further occurrences. No action is required if you have already submitted documentation outlining the causes of these violations and corresponding corrective actions.

Village of Seaman
Page 2

If there are any questions, please contact me at (740) 380-5277.

Sincerely,

A handwritten signature in black ink, appearing to read 'Aaron Wolfe', with a long horizontal flourish extending to the right.

Aaron Wolfe
Storm Water Coordinator
Division of Surface Water

AW/dh

c: Rick Hardin, Operator