



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

October 13, 2009

Re: Adams County
West Union WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PC00019
Correspondence (PWW)

Mayor and Council
P.O. Box 395
West Union, Ohio 45693

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of April 2009 through June 2009 for your wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	27.3	28.9391	5/1/2009
001	00530	Total Suspended Solids	40.9	70.9649	5/1/2009
001	00530	Total Suspended Solids	27.3	30.2478	6/1/2009
001	00530	Total Suspended Solids	18	19.5	6/8/2009
001	00530	Total Suspended Solids	40.9	59.7935	6/8/2009

Reporting Period	Station	Reporting Code	Parameter	Reported Value	Violation Date
May 2009	001	31616	Fecal Coliform	AK	5/6/2009
May 2009	001	31616	Fecal Coliform	AK	5/28/2009
May 2009	801	31616	Fecal Coliform	AK	5/28/2009
May 2009	901	31616	Fecal Coliform	AK	5/28/2009
June 2009	901	31616	Fecal Coliform	AK	6/25/2009
June 2009	001	31616	Fecal Coliform	AK	6/25/2009
June 2009	801	31616	Fecal Coliform	AK	6/25/2009

- * 1D Qty is equal to a maximum daily loading limit.
- 1D Conc is equal to the maximum daily concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Within 10 days from receipt of this letter submit a letter to this office outlining the reasons for the above permit violations and actions being taken to prevent further occurrences. No action is required if you have already submitted documentation outlining the causes of these violations and corresponding corrective actions.

If there are any questions, please contact me at (740) 380-5277.

Sincerely,



Aaron Wolfe
Storm Water Coordinator
Division of Surface Water

AW/dh

c: Richard Potter, Operator