



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 10, 2009

**Re:** Adams County  
West Union  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PC00019  
Correspondence (PWW)

Mayor and Council  
P.O. Box 395  
West Union, Ohio 45693

Dear Mayor and Council:

We have received your self-monitoring report covering the months of September 2008 through March 2009 for your wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	7D Conc	18	20.7	1/22/2009
001	00530	Total Suspended Solids	30D Qty	27.3	29.3101	1/1/2009
001	00530	Total Suspended Solids	7D Qty	40.9	56.9464	1/22/2009
001	00400	pH	1D Conc	9.0	9.6	3/25/2009

- \* 1D Qty is equal to a maximum daily loading limit.
- 1D Conc is equal to the maximum daily concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Within 10 days from receipt of this letter submit a letter to this office outlining the reasons for the above permit violations and actions being taken to prevent further occurrences. No action is required if you have already submitted documentation outlining the causes of these violations and corresponding corrective actions.

West Union  
Page 2

If there are any questions, please contact me at (740) 380-5277.

Sincerely,

A handwritten signature in black ink, appearing to read 'Aaron Wolfe', written over a horizontal line.

Aaron Wolfe  
Storm Water Coordinator  
Division of Surface Water

AW/dh

c: Richard Potter, Operator