



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

June 4, 2010

Re: Adams County
West Union High School WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. OPT00043
Correspondence (PWW)

Mr. Charles Kimble
West Union High School
141 Lloyd Road
West Union, Ohio 45693

Dear Mr. Kimble:

We have received your self-monitoring reports covering the months of January through March 2010 for your wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

| Station | Reporting Code | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|---------|----------------|-------------------------|------------|-------|----------------|----------------|
| 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Conc | 3 | 5.85 | 2/1/2010 |
| 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Qty | .0493 | .25375 | 2/1/2010 |
| 001 | 00610 | Nitrogen, Ammonia (NH3) | 1D Conc | 4.5 | 5.85 | 2/18/2010 |
| 001 | 00610 | Nitrogen, Ammonia (NH3) | 1D Qty | .222 | .25375 | 2/18/2010 |
| 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Conc | 3 | 4.33 | 3/1/2010 |
| 001 | 00610 | Nitrogen, Ammonia (NH3) | 30D Qty | .0493 | .16717 | 3/1/2010 |

- * 1D Qty is equal to a maximum daily loading limit.
- 1D Conc is equal to the maximum daily concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Within 10 days from receipt of this letter submit a letter to this office outlining the reasons for the above permit violations and actions being taken to prevent further occurrences. No action is required if you have already submitted documentation outlining the causes of these violations and corresponding corrective actions.

If there are any questions, please contact me at (740) 380-5277.

Sincerely,



Aaron Wolfe
Storm Water Coordinator
Division of Surface Water

AW/dh