



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 13, 2009

Re: Athens County
Burr Oak Regional Water District
Compliance Evaluation Inspection (CEI)
Correspondence (IWW-WP)

Mr. Kent Nichols, Plant Superintendent
Burr Oak Regional Water District
23554 Jenkins Dam Road
Glouster, Ohio 45732

Dear Mr. Nichols:

On April 8, 2009, a Compliance Evaluation Inspection (CEI) was conducted at the Burr Oak Regional Water District's plant. The purpose of the inspection was to determine Burr Oak's compliance with its National Pollutant Discharge Elimination System (NPDES) Permit. Present for the inspection were Kent Nichols representing Burr Oak, and Rex Haggy and Stephen Wells representing Ohio EPA, Southeast District Office. A copy of my inspection report is attached.

A walk through of the plant was conducted and operations observed. The discharge lagoons were observed and the discharge from the lagoon operating was observed. One of the lagoons was being de-watered to allow for the removal of solids. The plant is designed to operate on one lagoon while the other lagoon is allowed to dry out for the removal of solids.

In conclusion, Burr Oak Regional Water District appeared to be in compliance with its NPDES Permit at the time of the inspection.

No further response is requested to this letter. If you have any questions, feel free to contact me at (740) 380-5434.

Sincerely,

Stephen Wells
District Representative
Division of Surface Water

SW/dh

Enclosure

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0IV00010*ED	OH0030333	April 8, 2009	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Burr Oak Regional Water District Water Plant 23554 Jenkins Dam Road Glouster, Ohio	9:30 a.m.	April 1, 2008
	Exit Time	Permit Expiration Date
	10:45 a.m.	May 31, 2009

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Kent Nichols, Plant Superintendent	(740) 767-2558
Name, Address and Title of Responsible Official	Phone Number
Kent Nichols Burr Oak Regional Water District 23554 Jenkins Dam Road	(740) 767-2558

C. AREAS EVALUATED DURING INSPECTION

<u> </u> S Permit	<u> </u> S Flow Measurement	<u> </u> N/A Pretreatment
<u> </u> S Records/Reports	<u> </u> N Laboratory	<u> </u> N/A Compliance Schedules
<u> </u> S Operations & Maintenance	<u> </u> S Effluent/Receiving Waters	<u> </u> S Self-Monitoring Program
<u> </u> S Facility Site Review	<u> </u> S Sludge Storage/Disposal	<u> </u> Other
<u> </u> N/A Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


See attached report.



Stephen Wells, Inspector, Ohio EPA, Southeast District Office

5/14/09

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

5/14/09

Date