



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 13, 2009

Re: Athens County
Village of Albany
Notice of Violation
NPDES Permit #0PB00087*BD
Correspondence (PWW)

Mayor and Council
Village of Albany
5153 Alton Street
Albany, Ohio 45710

Dear Ladies and Gentlemen:

We have received your self-monitoring reports covering the months of October 2008 through March 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Units	Limit	Reported Value	Violation Date
January 2009						
001	Total Suspended Solids	7D Conc	mg/L	18	22.5	1/1/2009
001	Total Suspended Solids	30D Qty	Kg/day	5.9	6.39034	1/1/2009
001	Total Suspended Solids	7D Qty	Kg/day	8.9	16.9814	1/1/2009
001	CBOD 5 day	7D Qty	Kg/day	7.4	8.58249	1/1/2009

- *NOTES:**
- 1D Conc = Daily Average Concentration Value
 - 1D Qty = Daily Average Loading Value
 - 7D Conc = Weekly Average Concentration Value
 - 30D Conc = Monthly Average Concentration Value
 - 7D Qty = Weekly Average Loading Value
 - 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

Enclosure

c: Rick Verhotz, Operator
c: Tim Kirkendall, Albany Sewer Committee