



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

April 21, 2010

**Re: Athens County
Bassett House
NPDES Permit 0PX00008*CD
Notice of Violation
Correspondence (PWW)**

Mr. Rich Green
Health Recovery Services, Inc.
P.O. Box 724
Athens, Ohio 45701

Dear Mr. Green:

We have received your self-monitoring report covering the months of January through December 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type*	Units	Permit Limit	Reported	Date
June 2009						
002	Fecal Coliform	1D Conc	#/100ml	2000	2400	6/1/2009
002	Fecal Coliform	30D Conc	#/100ml	1000	2400	6/1/2009
September 2009						
002	Chlorine	1D Conc	mg/L	0.019	0.05	9/10/2009
October 2009						
002	Fecal Coliform	30D Conc	#/100ml	1000	1140	10/1/2009
December 2009						
001	Total Suspended Solids	30D Conc	mg/L	12	17	12/1/2009
001	Total Suspended Solids	30D Qty	Kg/day	0.11	0.16086	12/1/2009
001	CBOD 5 day	30D Conc	mg/L	10	12	12/1/2009
001	CBOD 5 day	30D Qty	Kg/day	0.09	0.11	12/1/2009
002	Total Suspended Solids	30D Qty	Kg/day	0.18	0.19	12/1/2009
002	Nitrogen, Ammonia	30D Conc	mg/L	5	24.5	12/1/2009
002	Nitrogen, Ammonia	30D Qty	Kg/day	0.076	0.46	12/1/2009
002	CBOD 5 day	30D Conc	mg/L	10	16	12/1/2009
002	CBOD 5 day	30D Qty	Kg/day	0.15	0.30	12/1/2009
002	Nitrogen, Ammonia	1D Conc	mg/L	7.5	24.5	12/7/2009

Outfall	Parameter	Type*	Units	Permit Limit	Reported	Date
002	Nitrogen, Ammonia	1D Qty	Kg/day	0.11	0.46	12/7/2009
002	CBOD 5 day	1D Conc	mg/L	15	16.	12/7/2009
002	CBOD 5 day	1D Qty	Kg/day	0.23	0.30	12/7/2009


*NOTES: 1D Conc = Daily Average Concentration Value
1D Qty = Daily Average Loading Value
7D Conc = Weekly Average Concentration Value
30D Conc = Monthly Average Concentration Value
7D Qty = Weekly Average Loading Value
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Bassett House must resolve these chronic effluent violations. We have received your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. However, your explanation is not satisfactory and we request, within ten days of receipt of this letter, written information as to what additional steps you will take to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

c: Mark Rutter
c: Jerry Smith, Buckeye Environmental