



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 9, 2010

Re: Athens County
Health Recovery Services
Bassett House & Women's Ctr.
NPDES Permit 0PX00008*CD
Notice of Violation
Correspondence (PWW)

Mr. Rich Green
Health Recovery Services, Inc.
P.O. Box 724
Athens, Ohio 45701

Dear Mr. Green:

We have received your self-monitoring report covering the months of January through March 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type*	Units	Permit Limit	Reported	Date
January 2010						
002	Nitrogen, Ammonia	30D Conc	mg/L	5	49	1/1/2010
002	Nitrogen, Ammonia	30D Qty	Kg/day	0.076	0.918	1/1/2010
002	Nitrogen, Ammonia	1D Conc	mg/L	7.5	48.5	1/13/2010
002	Nitrogen, Ammonia	1D Qty	Kg/day	0.11	0.92	1/13/2010
February 2010						
002	Nitrogen, Ammonia	30D Conc	mg/L	5	6.27	2/1/2010
002	Nitrogen, Ammonia	30D Qty	Kg/day	0.076	0.119	2/1/2010
002	Nitrogen, Ammonia	1D Qty	Kg/day	0.11	0.119	2/17/2010
March 2010						
002	Nitrogen, Ammonia	30D Conc	mg/L	5	8.5	3/1/2010
002	Nitrogen, Ammonia	30D Qty	Kg/day	0.076	0.161	3/1/2010
002	Nitrogen, Ammonia	1D Conc	mg/L	7.5	8.5	3/4/2010
002	Nitrogen, Ammonia	1D Qty	Kg/day	0.11	0.16	3/4/2010


***NOTES:** 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Health Recovery Services must resolve these chronic effluent violations. I have received your correspondence indicating the changes you have implemented and that you have contacted Rick Smith of Ohio EPA's Compliance Assistance Unit for assistance. Hopefully these actions will assist your facility in returning to compliance. No additional information is required at this time.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/mlm

- c: Patsy Bail, Admin. Coord., Health Recovery Services
- c: Rick Smith, Ohio EPA, DSW, CO