



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 18, 2011

Re: Athens County
Health Recovery Services
Bassett House & Women's Ctr.
NPDES Permit 0PX00008*CD
Notice of Violation
Correspondence (PWW)

Mr. Rich Green
Health Recovery Services, Inc.
P.O. Box 724
Athens, Ohio 45701

Dear Mr. Green:

We have received your self-monitoring report covering the months of July 2010 through June 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Month/Year	Outfall	Parameter	Type*	Limit	Reported	Date
September 2010	001	CBOD 5 day	30D Conc	10	13.1666	9/1/2010
September 2010	002	CBOD 5 day	30D Conc	10	20.05	9/1/2010
September 2010	001	CBOD 5 day	1D Conc	15	35.2	9/9/2010
September 2010	001	CBOD 5 day	1D Qty	0.14	.20651	9/9/2010
September 2010	001	Chlorine	1D Conc	0.019	1.87	9/9/2010
September 2010	002	CBOD 5 day	1D Conc	15	40.8	9/16/2010
September 2010	002	CBOD 5 day	1D Qty	0.23	.25481	9/16/2010
September 2010	002	CBOD 5 day	1D Conc	15	26.6	9/23/2010
September 2010	002	Chlorine	1D Conc	0.019	1.09	9/29/2010
October 2010	001	Chlorine	1D Conc	0.019	.05	10/6/2010
October 2010	002	Chlorine	1D Conc	0.019	.3	10/6/2010
October 2010	002	Chlorine	1D Conc	0.019	.1	10/15/2010
January 2011	002	Nitrogen, Ammonia	30D Conc	5	16.45	1/1/2011
January 2011	002	Nitrogen, Ammonia	30D Qty	0.076	.10273	1/1/2011
January 2011	002	Nitrogen, Ammonia	1D Conc	7.5	20.6	1/12/2011
January 2011	002	Nitrogen, Ammonia	1D Qty	0.11	.12865	1/12/2011
January 2011	002	Nitrogen, Ammonia	1D Conc	7.5	12.3	1/26/2011
April 2011	002	Nitrogen, Ammonia	30D Conc	5	12.465	4/1/2011
April 2011	002	Nitrogen, Ammonia	30D Qty	0.076	.07785	4/1/2011
April 2011	002	Nitrogen, Ammonia	1D Conc	7.5	15.4	4/13/2011
April 2011	002	Nitrogen, Ammonia	1D Conc	7.5	9.53	4/27/2011

Month/Year	Outfall	Parameter	Type*	Limit	Reported	Date
May 2011	001	Total Suspended Solids	30D Conc	12	13.	5/1/2011
May 2011	002	Total Suspended Solids	30D Conc	12	13.	5/1/2011
June 2011	002	Chlorine	1D Conc	0.019	.07	6/1/2011


*NOTES: 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
 Environmental Engineer
 Permits and Enforcement Section
 Division of Surface Water

AS/dh

c: Patsy Bail, Admin. Coord., Health Recovery Services
 c: Rick Smith, Ohio EPA, DSW, CO