

Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 18, 2011

Re: Athens County
Capstone Village
Notice of Violation
Permit OPW00018*BD
Correspondence (PWW)

Mr. Bob Prebe
Capstone Village
8644 United Lane
Athens, Ohio 45701

Dear Mr. Prebe:

We have received your self-monitoring reports covering the months of May 2010 through June 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Month/Year	Outfall	Parameter	Type	Limit	Reported	Date
October 2010	001	Fecal Coliform	30D Conc	1000	1600.	10/1/2010
January 2011	002	Nitrogen, Ammonia	1D Conc	4.5	7.88	1/12/2011
January 2011	002	Nitrogen, Ammonia	1D Qty	0.4	.71582	1/12/2011
April 2011	001	Nitrogen, Ammonia	30D Conc	3	4.91	4/1/2011
April 2011	001	Nitrogen, Ammonia	30D Qty	.17	.27877	4/1/2011
April 2011	001	Nitrogen, Ammonia	1D Conc	4.5	4.91	4/13/2011
April 2011	001	Nitrogen, Ammonia	1D Qty	.26	.27877	4/13/2011


***NOTES:** 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have received your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Your explanation does not provide enough detail to assure us that the violations will not continue. We request, within ten days of receipt of this letter, written information as to what additional steps you will take to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,

A handwritten signature in black ink, appearing to read 'Abbot Stevenson', with a long horizontal flourish extending to the right.

Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh