



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 15, 2007

Re: ~~Athens County~~
~~Village of Chauncey~~
Compliance Inspection
NPDES Permit 0PB00006*GD
Correspondence (PWW)

Mayor and Council
Village of Chauncey
42 Converse Street
Chauncey, Ohio 45719

Dear Mayor and Council:

On January 8, 2007, Cynthia Yandrich and I, representing Ohio EPA, conducted a compliance evaluation inspection of the Village of Chauncey waste water treatment plant. Steve Grant and Eric Phillips accompanied us during the inspection and represented the Village of Chauncey. The purpose of the inspection was to determine if waste water treatment system was meeting the terms and conditions set forth in the NPDES Permit.

The following observations were made during the inspection.

1. At the time of the inspection, one of the influent wet well pumps was inoperable. Mr. Grant and Mr. Phillips indicated that items required for repair had been ordered and the pump should be operational soon. Please make every effort to repair/replace the damage pump as soon as possible, as a back-up pump is very important in the case of pump failure in the wet well.

With exception of the influent wet well pump, the Chauncey waste water treatment plant appeared to be in good operating condition and well maintained.

Please respond to this letter within fifteen (15) days of receipt. In your response, please provide the status of the influent pump repairs. If you have any questions or concerns, feel free to contact me at (740) 380-5226.

Sincerely,

Patrick Hudnall
Division of Surface Water

PH/mlm

c: Steve Grant
c: Eric Phillips

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PB00006	OH0024368	January 8, 2007	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Chauncey WWTP	2:00 pm	June 1, 2005
	Exit Time	Permit Expiration Date
	3:00 pm	May 31, 2010

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Eric Phillips, Contract Operator Steve Grant	740.704.3872 740.797.2031
Name, Address and Title of Responsible Official	Phone Number
Mayor and Council 42 Converse Street Chauncey, Ohio 45719	740.797.2031


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>N</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u> </u> Other
<u>N</u> Collection System		


(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.


Patfick Hudnall, Inspector, Ohio EPA, Southeast District Office

2/15/07
Date


Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

2/15/07
Date