



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 18, 2011

**Re: Athens County
Happy Valley Estates MHP
Notice of Violation
Permit 0PV00531*BD
Correspondence (PWW)**

Mr. Asa Elsea, President
Elsea, Inc.
P.O. Box 580
Circleville, Ohio 43113

Dear Mr. Elsea:

We have received your self-monitoring reports covering the months of January 2010 through June 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Month/Year	Outfall	Parameter	Type*	Limit	Reported	Date
January 2011	001	Nitrogen, Ammonia	30D Conc	3.0	3.05	1/1/2011
March 2011	001	Total Suspended Solids	30D Conc	12	14.	3/1/2011
March 2011	001	Total Suspended Solids	30D Qty	0.636	.72445	3/1/2011
March 2011	001	Nitrogen, Ammonia	30D Conc	3.0	3.6	3/1/2011
March 2011	001	Nitrogen, Ammonia	30D Qty	0.159	.16351	3/1/2011
March 2011	001	CBOD 5 day	30D Conc	10	10.5	3/1/2011
March 2011	001	CBOD 5 day	30D Qty	0.53	.57229	3/1/2011
March 2011	001	CBOD 5 day	1D Qty	0.795	.82664	3/16/2011
April 2011	001	Nitrogen, Ammonia	30D Qty	0.159	.19209	4/1/2011
April 2011	001	Nitrogen, Ammonia	1D Conc	4.5	5.2	4/6/2011
April 2011	001	Nitrogen, Ammonia	1D Qty	0.239	.37396	4/6/2011
April 2011	001	Nitrogen, Ammonia	1D Qty	0.954	1.27933	4/27/2011
May 2011	001	Nitrogen, Ammonia	30D Conc	1.0	2.25	5/1/2011
May 2011	001	Nitrogen, Ammonia	30D Qty	0.053	.07097	5/1/2011
May 2011	001	Fecal Coliform	30D Conc	1000	10000.	5/1/2011
May 2011	001	Nitrogen, Ammonia	1D Conc	1.5	4.	5/4/2011
May 2011	001	Nitrogen, Ammonia	1D Qty	0.080	.10598	5/4/2011
May 2011	001	Fecal Coliform	1D Conc	2000	10000.	5/26/2011

*NOTES: 1D Conc = Daily Average Concentration Value
1D Qty = Daily Average Loading Value
7D Conc = Weekly Average Concentration Value
30D Conc = Monthly Average Concentration Value
7D Qty = Weekly Average Loading Value
30D Qty = Monthly Average Loading Value

Please be advised that failure to satisfy the reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

c: Tom Bouts, Operator
c: Mary Harrison-Reed, Elsea, Inc.