



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 4, 2010

**Re:** Athens County  
Happy Valley Estates MHP  
SNC Notice of Violation  
Permit OPV00531\*BD  
Correspondence (PWW)  
\*\*Correction\*\*

Mr. Asa Elsea, President  
Elsea, Inc.  
P.O. Box 580  
Circleville, Ohio 43113

Dear Mr. Elsea:

We have received your self-monitoring reports covering the months of April through September 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type	Units	Limit	Reported	Date
<b>July 2009:</b>						
001	Nitrogen, Ammonia	30D Conc	mg/L	1.0	11.425	7/1/2009
001	Nitrogen, Ammonia	30D Qty	Kg/day	0.053	0.389	7/1/2009
001	Nitrogen, Ammonia	1D Conc	mg/L	1.5	7.6	7/5/2009
001	Nitrogen, Ammonia	1D Qty	Kg/day	0.080	0.259	7/5/2009
001	Nitrogen, Ammonia	1D Conc	mg/L	1.5	17.8	7/14/2009
001	Nitrogen, Ammonia	1D Qty	Kg/day	0.080	0.606	7/14/2009
001	Nitrogen, Ammonia	1D Conc	mg/L	1.5	18.6	7/19/2009
001	Nitrogen, Ammonia	1D Qty	Kg/day	0.080	0.634	7/19/2009
001	Fecal Coliform	1D Conc	#/100ml	2000	3600	7/19/2009
001	Nitrogen, Ammonia	1D Conc	mg/L	1.5	1.7	7/26/2009
<b>August 2009:</b>						
001	Nitrogen, Ammonia	30D Conc	mg/L	1.0	8.8	8/1/2009
001	Nitrogen, Ammonia	30D Qty	Kg/day	0.053	0.300	8/1/2009
001	Chlorine	1D Conc	mg/L	0.019	1.13	8/4/2009


001	Dissolved Oxygen	1D Conc	mg/L	6.0	3.5	8/12/2009
001	Nitrogen, Ammonia	1D Conc	mg/L	1.5	25.3	8/16/2009
001	Nitrogen, Ammonia	1D Qty	Kg/day	0.080	0.862	8/16/2009
001	Chlorine	1D Conc	mg/L	0.019	0.07	8/16/2009
001	Dissolved Oxygen	1D Conc	mg/L	6.0	4.1	8/16/2009
<b>September 2009:</b>						
001	Chlorine	1D Conc	mg/L	0.019	0.08	9/1/2009

Please be advised that failure to satisfy the reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/mlm

c: Tom Bouts, Operator  
c: Mary Harrison-Reed, Elsea, Inc.  
c: AS file