



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 6, 2010

Re: Athens County
Cool Spot Convenience Store
NPDES Permit OPR00127*CD
Reconnaissance Inspection
Correspondence (PWW)

Mr. Bryan White
Cool Spot Convenience Store
P.O. Box 502
Coolville, Ohio 45723

Dear Mr. White:

On March 2, 2010, I inspected the wastewater treatment system serving the Cool Spot Convenience Store located in Coolville, Athens County. The purpose was to evaluate the condition of the wastewater treatment plant. A copy of the inspection report is attached.

At the time of the inspection, a worker was inspecting the grease and trash traps. He reported that these two tanks were going to be pumped that day. There were insulating covers on the aeration plant. The clarifier had pin floc on the surface of the clarifier and in the weirs. One sand filter was clogged, but the other one was clean. The chlorination tank was free of sludge and the effluent appeared clear.

There is no need to respond to this letter. If you have any questions please call Abbot Stevenson at (740) 380-5284.

Sincerely,

Cynthia Yandrich
District Representative
Division of Surface Water

CY/dh

Enclosure

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPR00127*CD	OH0124621	March 2, 2010	R	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Cool Spot Convenience Store 25780 Brimstone Road Coolville, Ohio, Athens County	10:40 a.m.	July 1, 2007
	Exit Time	Permit Expiration Date
	10:54 a.m.	June 30, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Unknown	
Name, Address and Title of Responsible Official	Phone Number
Mr. Bryan White Cool Spot Convenience Store P.O. Box 502 Coolville, Ohio 45723	(740) 667-6001

C. AREAS EVALUATED DURING INSPECTION

<u> </u> N Permit	<u> </u> N Flow Measurement	<u> </u> N Pretreatment
<u> </u> N Records/Reports	<u> </u> N Laboratory	<u> </u> N Compliance Schedules
<u> </u> M Operations & Maintenance	<u> </u> S Effluent/Receiving Waters	<u> </u> N Self-Monitoring Program
<u> </u> S Facility Site Review	<u> </u> N Sludge Storage/Disposal	<u> </u> Other
<u> </u> N Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.



Cynthia Yandrich, Inspector, Ohio EPA, Southeast District Office

4-5-10

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

4/5/10

Date