



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6480
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

April 9, 2007

Re: Athens County
Arcadia Nursing Center
Compliance Evaluation Inspection
NPDES Permit OPR00096*CD
Correspondence (PWW)

Responsible Official
P.O. Box 511
Coolville, Ohio 45723

Dear Sir or Madam:

On April 2, 2007, I conducted a Compliance Evaluation Inspection (CEI) for the waste water treatment plant (WWTP) serving the Arcadia Nursing Center. Chris Catlett and Jerry Smith (Buckeye Environmental Services) accompanied me during the inspection. The purpose of the inspection was to determine compliance with the terms and conditions set forth in the NPDES Permit.

During the inspection all treatment units in the plant appeared to be good operating condition.


Please be aware, the Ohio EPA has recently finalized new operator certification rules which set requirements for minimum staffing requirements among other things. The final rule is Ohio Administrative Code (OAC) 3745-07 and can be viewed in its entirety at <http://www.epa.state.oh.us/ddagw/oac.html#374507>. The minimum staffing requirements will not be effective until the Arcadia Nursing Center WWTP NPDES Permit is renewed, but all other aspects of the new rule were effective December 21, 2006. Of note, these new rules require the Operator of Record (owner of Arcadia Nursing Center) maintain a log book documenting daily activities at the plant. The specific requirements of the log book are listed in the rule. I encourage you to read the rule and contact me with any questions you may have.

Arcadia Nursing Center

Page 2

Should you have any questions or concerns, feel free to contact me at (740) 380-5226.

Sincerely,



Patrick Hudnall
District Representative
Division of Surface Water

PH/dh

Enclosure

- c: Jerry Smith, Buckeye Environmental Services
- c: Chris Catlett, Maintenance Supv., Arcadia Nursing Center

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPR00096*CD	OH0108154	April 2, 2007	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Arcadia Nursing Center WWTP	11:00 a.m.	May 1, 2006
	Exit Time	Permit Expiration Date
	11:45 a.m.	April 30, 2011

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Chris Catlett, Maintenance Supervisor Jerry Smith, Tech. Assist./Sampling	(740) 667-3156 (740) 342-9191
Name, Address and Title of Responsible Official	Phone Number
Owner, Arcadia Nursing Center	(740) 667-3156

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N</u> Pretreatment
<u>S</u> Records/Reports	<u>N</u> Laboratory	<u>S</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u> </u> Other
<u>M</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


See attached inspection letter.



Patrick Hudnall, Inspector, Ohio EPA, Southeast District Office

4/9/07

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

4/9/07

Date