



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 5, 2011

**Re:** Athens County  
Spreading Oaks MHP  
Compliance Evaluation Inspection  
Ohio EPA Permit No. 0PV00001\*FD  
NPDES Permit No. OH0051110  
Correspondence (PWW)

Mr. Jeff Yorick, VP Engineering  
UMH Properties  
1275 Forman Drive  
Morgantown, WV 26508

Dear Mr. Yorick:

On June 16, 2011, I conducted a compliance evaluation inspection at the Spreading Oaks Mobile Home Park Wastewater Treatment Plant (WWTP). Paul Brooks, Park Manager, and Rick Verhotz, Plant Operator, accompanied me during the inspection. The purpose of the inspection was to determine the facility's status of compliance with the terms and conditions set forth in its National Pollutant Discharge Elimination System (NPDES) Permit, 0PV00001\*GD.

As a result of the inspection, I have the following comments:

1. Previous inspection reports indicated that the park suffers from Infiltration and Inflow problems in the sewers. It appears that most of the sewers have been replaced, with about 25% remaining to be done. The impact of this work is already being seen in the operation of the plant. It is strongly recommended that the project be completed by replacing the remaining 25% of the collection system.
2. Samples must be refrigerated (on ice) between the time the sample is taken until delivered to the laboratory.

A copy of our inspection form is enclosed with this letter. Please reply to Items 1 and 2 above within 30 days of receipt of this report. If you have any questions or comments, please contact me at (740) 380-5284.

Sincerely,

A handwritten signature in black ink, appearing to read 'Abbot Stevenson', with a long horizontal flourish extending to the right.

Abbot Stevenson  
Environmental Engineer  
Permits and Compliance Section  
Division of Surface Water

AS/dh

Enclosure

- c: Paul Brooks, Spreading Oaks Village MHP
- c: Rick Verhotz, Stantec Consulting

# NPDES Compliance Inspection Report

## A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPV00001*GD	OH0051110	June 16, 2011	C	S	1

## B. FACILITY DATA

Name & Location of Facility Inspected	Entry Time	Permit Effective Date
Spreading Oaks Mobile Home Park 7140-29 Selby Road Athens, Ohio 45701	7:45 a.m.	April 1, 2008
	Exit Time	Permit Expiration Date
	8:45 a.m.	March 31, 2013

Name(s) & Title(s) of On-Site Representative(s)	Phone Number(s)
Paul Brooks, Park Manager	(740) 593-3952
Name, Address, & Title of Responsible Official	Phone Number
Jeff Yorick, VP Engineer UMH Properties 1275 Forman Drive Morgantown, WV 26508	(304) 291-3380

## C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>M</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u>    </u> Other
<u>S</u> Collection System		


(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated; N/A = Not Applicable)

## D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

1. Collection System - finish sewer replacement for I/I removal.
2. Laboratory - samples must be refrigerated.

  
 Abbot Stevenson, Inspector, Ohio EPA, Southeast District Office

7/5/11  
 Date

  
 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

7/5/11  
 Date

**E. PERMIT VERIFICATION**

Inspection Observations, Verify the Permit	YES	NO	N/A	N/E
a. Correct name & mailing address of permittee	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Correct name & location of receiving waters	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. Product(s) & production rates conform with permit application (industries)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d. Flows & loadings conform with NPDES permit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. Treatment processes are as described in permit application/briefing memo	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
f. New treatment process(es) added since last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
g. Notification given to state of new, different, or increased discharges	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
h. All discharges are permitted	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
i. Number & location of discharge points are as described in permit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:

**F. COMPLIANCE SCHEDULES/VIOLATIONS**

	YES	NO	N/A	N/E
a. Any significant violations since the last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Permittee is taking actions to resolve violations	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
c. Permittee has compliance schedule	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Compliance schedule contained in: _____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
e. Permittee is meeting compliance schedule	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Comments:

**G. OPERATION AND MAINTENANCE**

Treatment Facility Properly Operated & Maintained	YES	NO	N/A	N/E
a. Standby power available: Generator: <input type="checkbox"/> Dual Feed: <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Adequate alarm system available for power or equipment failures	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. All treatment units in service other than backup units	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Sufficient operating staff provided: # of shifts: <u>1</u> Days/Week: <u>5</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. Operator holds unexpired license of class required by permit. Class: _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
f. Copy of certificate of Operator of Record displayed on-site	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
g. Minimum operator staffing requirements fulfilled (OAC 3745-7)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
h. Routine & preventive maintenance schedule/performed on time	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
i. Any major equipment breakdown since last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
j. Operation & maintenance manual provided & maintained	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
k. Any plant bypasses since last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
l. Regulatory agency notified of bypasses: On MORS: <input type="checkbox"/> 800 No.: <input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
m. Any hydraulic and/or organic overloads experienced since last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:

Record Keeping	YES	NO	N/A	N/E
a. Log book provided	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Log book kept on-site	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. Log book contains the following:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1. Identification of treatment works	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Date/Time of arrival/departure of ORC	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Daily record of operation and maintenance activities	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Laboratory results (unless documented on bench sheets)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Identification of person making log entries	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Is the ORC submitting written notification to Ohio EPA and permittee when a collection system overflow, treatment plant bypass or effluent limit violation has occurred.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**Comments:**

a. Log book is very detailed.

Collection System	YES	NO	N/A	N/E
a. Percent combined system. Percent: <u>0</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
b. Any collection system overflows since last inspection: CSO: <input type="checkbox"/> SSO: <input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. Regulatory agency notified of overflow (SSOs)	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d. CSO O&M plan provided and implemented	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
e. CSOs monitored and reported in accordance with permit	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
f. Portable pumps used to relieve system	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
g. Lift station alarm systems provided and maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
h. Are lift stations equipped with permanent standby power or equivalent	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
i. Is there an inflow/infiltration problem (separate sewer system), or were there any major repairs to collection system since last inspection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
j. Any complaints received since last inspection of basement flooding	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
k. Are any portions of the sewer system at or near capacity	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**Comments:**

i. Facility has had I/I problems in the past. As a result, owner has replaced 75% of the sewers. It is recommended that project be completed - finish replacing sewers and repairing manholes.

**H. SLUDGE MANAGEMENT**

	YES	NO	N/A	N/E
a. Sludge adequately disposed. Method: <u>hauled to POTW (Lancaster)</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. If sludge is incinerated, where is ash disposed of? _____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
c. Is sludge disposal contracted? Name: <u>Trace</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Has amount of sludge generated changed significantly since last inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. Adequate sludge storage provided at facility	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
f. Land application sites monitored and inspected per state rules	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
g. Records kept in accordance with state rules	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
h. Any complaints received in last year regarding sludge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
i. Is sludge adequately processed (digestion, dewatering, pathogen control) in accordance with Ohio EPA rules	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

I. SELF-MONITORING PROGRAM

Part 1 Flow Measurement	YES	NO	N/A	NE
a. Primary flow measuring device properly operated & maintained. Type of device: <input type="checkbox"/> Ultrasonic & parshall flume <input type="checkbox"/> Calculated from influent <input type="checkbox"/> Weir <input type="checkbox"/> Other <input checked="" type="checkbox"/> Ultrasonic & weir      specify: _____	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Calibration frequency adequate. Date of last calibration: <u>1/2011</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. Secondary instruments (totalizers, recorders, etc.) properly operated and maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d. Flow measurement equipment adequate to handle expected ranges of flows	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. Actual flow discharged is measured	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
f. Flow measuring equipment inspection frequency: <input checked="" type="checkbox"/> Daily <input type="checkbox"/> Monthly <input type="checkbox"/> Weekly <input type="checkbox"/> Other				

Comments:

Part 2 Sampling	YES	NO	N/A	NE
a. Sampling location(s) are as specified by permit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Parameters and sampling frequency agree with permit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. Permittee uses required sampling method	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Sample collection procedures are adequate	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
i. Samples refrigerated during compositing	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
ii. Proper preservation techniques used	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Conform with 40 CFR 136.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. Monitoring records (e.g., flow, pH, D.O., etc.) maintained for a minimum of three years including all original strip chart recordings (e.g., continuous monitoring instrumentation, calibration, & maintenance records)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
f. Adequate records maintained of sampling date, time, exact location, etc.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Comments:

Part 3 Laboratory General	YES	NO	N/A	NE
a. Written Standard Operating Procedures (SOPs) for all analysis performed on-site	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. EPA approved analytical testing procedures used (40 CFR 136.3)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. If alternate analytical procedures are used, proper approval has been obtained	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d. Analysis being performed more frequently than required by permit	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. If (c) is yes, are results reported in permittee's self-monitoring report	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
f. Commercial laboratory used: 1. Parameters analyzed by commercial lab: <u>All except DO and chlorine</u> 2. Lab name: <u>Pace Analytical</u>				

Comments:

Part 3 Laboratory Quality Control/Quality Assurance	YES	NO	N/A	NE
a. Quality assurance manual provided and maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
b. Satisfactory calibration and maintenance of instruments and equipment	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
c. Adequate records maintained	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
d. Results of latest U.S. EPA quality assurance performance sampling program: Date: _____ <input type="checkbox"/> Satisfactory <input type="checkbox"/> Marginal <input type="checkbox"/> Unsatisfactory				

Comments:

## J. EFFLUENT/RECEIVING WATER OBSERVATIONS

Outfall #	Oil Sheen	Grease	Turbidity	Visible Foam	Visible Float Solids	Color	Other
001	None	None	None	None	None	None	

Comments:

## K. MULTIMEDIA OBSERVATIONS

Collection System	YES	NO	N/A	NE
a. Are there indications of sloppy housekeeping or poor maintenance in work and storage areas or laboratories	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
b. Do you notice staining or discoloration of soils, pavement, or floors	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
c. Do you notice distressed (unhealthy, discolored, dead) vegetation	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
d. Do you see unidentified dark smoke or dustclouds coming from sources	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
e. Do you notice any unusual odors or strong chemical smells	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
f. Do you see any open or unmarked drums, unsecured liquids, or damaged containment facilities	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

If any of the above are observed, ask the following questions:

1. What is the cause of the conditions?
2. Is the observed condition or source a waste product?
3. Where is the suspected contaminant normally disposed?
4. Is this disposal permitted?
5. How long has the condition existed and when did it begin?

Comments:

## General Lab Criteria

Facility: Spreading Oaks MHP

Criteria	Standard Methods Requirement	Acceptable?		Rating
<b>Balance</b>				
• Standard Weights	• Either NIST Class S or ASTM/ANSI Class 1 weights <sup>1,2</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Frequency/ Documentation	• Calibration verification required at least once each day the balance is used <sup>3</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Cleanliness, air movement, vibration	• Cleanliness of balance is a must and air movement and vibration needs to be kept to a minimum <sup>1</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Service and recalibrate annually (manufacturer representative or comparable) <sup>1</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Must be able to measure to 0.1 grams <sup>4</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book maintained <sup>5</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: N/A				

Criteria	Standard Methods Requirement	Acceptable?		Rating
<b>Drying Oven (Suspended Solids)</b>				
• Temperature Recordkeeping	• Temperature recorded with each use <sup>4</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book maintained <sup>6</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Frequency/ Documentation	• Thermometer calibrated annually with NIST traceable thermometer <sup>1,2</sup> . Correction factor posted on thermometer/equipment <sup>1</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Thermometer temperature in 0.1°C increments <sup>5</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Acceptable temperature range is 103° – 105°F <sup>4</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: N/A				

Criteria	Standard Methods Requirement	Acceptable?		Rating
<b>pH Meter</b>				
• Calibration Frequency/ Documentation	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) <sup>3</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book maintained <sup>9</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Minimum of 2 point calibration	• Calibration per manufacturer specification and calibration buffers must bracket anticipated result <sup>7</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Slope Documentation/ Acceptability	• Slope acceptable range indicated on benchsheet <sup>2</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Buffer Expiration Date	• Buffers must not be expired	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Instrument manual available	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Teflon covered magnetic stirrer or equivalent for mixing <sup>8</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: N/A				

## General Lab Criteria

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Dissolved Oxygen Meter</b>			<b>A</b>
• Calibration Method	• Air or known DO calibration method <sup>10</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Calibration per manufacturer specification <sup>10</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Calibration Frequency/ Documentation	• Logbook maintained <sup>9</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Calibration verification required at least once each day the meter is used. <sup>3</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Small to no bubble present under membrane (must be smaller than the lead in number 2 pencil) <sup>11</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Instrument manual available	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Comments:			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Incubator (CBOD/E-Coli)</b>			
• Temperature Recordkeeping	• Temperature checked/recorded twice daily for each shelf in use <sup>1</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Temperature checked/recorded daily <sup>2</sup> (CBOD)	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Acceptable temperature range (CBOD) is 20°C ±1.0° <sup>12</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Acceptable temperature range (E-Coli) is 35°C ±0.5° <sup>22</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Logbook maintained <sup>9</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• Temperature Calibration/ Documentation	• Thermometer calibrated annually with NIST traceable thermometer <sup>1,2</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Temperature correction information posted on incubator <sup>1</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• E-Coli can use multiple tubes (five 20 ml or ten 10 mg), or mfg's multi-well tray	• E-coli Ultraviolet lamp (365 nm wave length, 6 W bulb) <sup>23</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Instrument manual available	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Temperature Log (thermometer reads to 0.1 Celsius) <sup>5</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Comments: N/A			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Refrigerator</b>			
• Temperature Recordkeeping	• Temperature Log (thermometer reads to 0.1 Celsius) <sup>5</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• Temperature Calibration/ Documentation	• Thermometer calibrated annually with NIST traceable thermometer <sup>1,2</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
• Other	• Thermometer held in water bath <sup>1</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Refrigerator temperature ≤6° Celsius <sup>13</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Do not store volatile solvents, food, or beverages <sup>14</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Comments: N/A			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Chlorine Meter</b>			
• Calibration Frequency/ Documentation	• pH/millivolt meter read to 0.1 mV <sup>15</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) <sup>3</sup>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
• Calibration Method	• Calibration using three iodate solutions 0.2, 1.0, 5.0 milliliters	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

## General Lab Criteria

	or calibration per manufacturer specification <sup>16</sup>			
• Slope Documentation/ Acceptability	• Standards used for calibration not expired	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Calibration curve (acceptable slope)	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
• Other	• Electrode free of deposits and foreign material	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> NA	
	• Log book being maintained <sup>9</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments:				

Criteria	Standard Methods Requirement	Acceptable?		Rating
<b>Ammonia Meter</b>				
• Calibration Frequency/ Documentation	• Calibration verification required for testing over long period of time (e.g. 12 hrs.), or after a large number of samples (every 10 samples) <sup>3</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
		• Log book being maintained <sup>9</sup>	<input type="checkbox"/> Yes	
• Slope Acceptability	• Verify calibration slope is acceptable (per mfg. spec.)	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
• Calibration Method	• Standards used for calibration (3 ammonia solutions of 10 mg/l, 1 mg/l, and 0.1 mg/l) or per mfg. spec. <sup>17</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
		• Standards used for calibration not expired	<input type="checkbox"/> Yes	
• Other	• Electrode free of deposits and foreign material	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Teflon covered magnetic stirrer or equivalent for mixing <sup>18</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Instrument manual available	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: N/A				

Criteria	Standard Methods Requirement	Acceptable?		Rating
<b>Sample Collection/Handling</b>				<b>A</b>
• Sample Labeling	• Samples container labeled (description, date, time, preservative added, initialed) <sup>19</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Chain of Custody	• Chain of custody (description, date, time, signature) <sup>19</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
• Other	• Composite samples refrigerated during sample collection <sup>14</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Equipment blanks utilized <sup>14</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• SOP for cleaning of sampling equipment	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
	• Log book being maintained <sup>9</sup>	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments:				

Criteria	Standard Methods Requirement	Acceptable?		Rating
<b>Desiccator</b>				
• General Criteria	• Properly working seals	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
		• Desiccant fresh (blue color)	<input type="checkbox"/> Yes	
• Documentation	• Log book being maintained <sup>9</sup>	<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Comments: N/A				

## General Lab Criteria

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Bench Sheets</b>			
<ul style="list-style-type: none"> <li>• General Criteria</li> </ul>	• Date(s) <sup>2</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Analyst initials <sup>2</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Blue or black ink pen <sup>2</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Calibration information <sup>2</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Equations, calculations, units for all measurements, notations, and results present <sup>2</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	• Corrections, single line through, initialed and dated <sup>2</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Comments: N/A			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Hot Water Bath (Fecal Coliform/E. coli)</b>			
<ul style="list-style-type: none"> <li>• Temperature Recordkeeping</li> </ul>	• Temperature Log (thermometer reads 0.2° C) <sup>21</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
		• Incubator temperature 44.5° C ±0.2° <sup>21/24</sup>	
<ul style="list-style-type: none"> <li>• Temperature Calibration/ Documentation</li> </ul>	• Thermometer calibrated annually with NIST traceable thermometer <sup>1,2</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
		• Log book being maintained <sup>9</sup>	
<ul style="list-style-type: none"> <li>• Water Level</li> </ul>	• Thermometer total immersion or partial (line on thermometer to ID immersion depth) <sup>1,5</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Comments: N/A			

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Autoclaves/Steam Sterilizers</b>			
<ul style="list-style-type: none"> <li>• All apparatus utilized is adequately sterilized before use</li> </ul>	• Sterilizing temperature 121° C <sup>25</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
		• 10 to 30 minutes time based on material being sterilized <sup>26</sup>	
<ul style="list-style-type: none"> <li>• Documentation</li> </ul>	• Verify the autoclave temperature weekly by using a maximum registering thermometer (MRT) to confirm that 121°C has been reached as measured in the exhaust <sup>1</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
		• Date, contents, sterilization time and temperature, total time in autoclave, and analyst's initials should be recorded each time the autoclave is used <sup>1</sup>	
<ul style="list-style-type: none"> <li>• Temperature Calibration/ Documentation</li> </ul>	• Thermometer calibrated annually with NIST traceable thermometer <sup>1,2</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
		• Log book being maintained <sup>9</sup>	
<ul style="list-style-type: none"> <li>• Performance Checks</li> </ul>	• Test monthly for efficacy using a biological such as commercially available <i>Geobacillus stearothermophilus</i> in spore strips, suspensions, or capsules <sup>1</sup>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Comments: N/A			

## General Lab Criteria

Criteria	Standard Methods Requirement	Acceptable?	Rating
<b>Final Effluent Temperature Monitoring</b>			
<ul style="list-style-type: none"> <li>• General Criteria</li> </ul>	<ul style="list-style-type: none"> <li>• Thermometer calibrated annually with NIST traceable thermometer<sup>1,2</sup></li> </ul>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	<ul style="list-style-type: none"> <li>• Thermometer reads in increments of at least 0.1°C<sup>5</sup></li> </ul>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
	<ul style="list-style-type: none"> <li>• Log book being maintained<sup>2</sup></li> </ul>	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Comments: N/A			

<b>Number of Criteria Rated:</b>	<b>Acceptable</b>	3
	<b>Marginal</b>	
	<b>Unacceptable</b>	
	<b>Total Number of Areas Rated</b>	3

<b>Acceptable Ratings</b> – No action required (recommend SOP's written or updated, perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, written response not required).	
<b>Marginal Ratings</b> – Improvements required, written response required (recommend SOP's be written or updated, recommend they perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, require deficiencies to be addressed in written response).	
<b>Unsatisfactory Rating</b> – Improvements required, written response required, NOV issued (recommend SOP's be written or updated, recommend they perform DMRQA's for all onsite analysis, recommend voluntary lab analyst certification, require deficiencies to be addressed in written response to NOV).	
Consider recommending PAI Audit from DES when:	<ul style="list-style-type: none"> <li>&gt;60% of ratings are Marginal</li> <li>&gt;45% of ratings are a combination of Marginal or Unacceptable</li> <li>&gt;30% of ratings are Unacceptable</li> </ul>

# General Lab Criteria

## Notation of Referenced Method

1	Method 9020-B, Item 4	14	Method 1060A, Item 1
2	Method 1020-A, Item 1	15	Method 4500-CI I, Item 2
3	Method 1020-B, Item 10	16	Method 4500-CI I, Item 4
4	Method 2540-B, Item 2	17	Method 4500-NH3 D, Item 4
5	Method 2550-B, Item 1	18	Method 4500-NH3 D, Item 2
6	Method 1020-B, Item 1	19	Method 1060-B, Item 2
7	Method 4500-H B, Item 4	20	Method 1060-B, Item 1
8	Method 4500-H B, Item 2	21	Method 9222D, Item 1
9	Method 1020-B, Item 2	22	Method 9223 B, Item 2
10	Method 4500-O B, Item 3	23	Method 9223 B, Item 3
11	Method 4500-O G, Item 3	24	Method 1603, Item 2
12	Method 5210-B, Item 5	25	Method 9030-B, Item 3
13	CFR 136.3, Table II	26	Method 9020 B, Table IV

**Equipment Logbook Content** – All maintenance performed on a piece of equipment should be documented in the logbook. This should include parts replacement and routine maintenance activities. Entries should include date, maintenance performed and initials of person making entry.

Preservation and Holding Times						
Parameter	Container	Min. Sample Size (mL)	Sample Type	Preservation	Maximum Storage Time	
					Recommended	Regulatory
BOD / CBOD	P, G	1000	G, C	Refrigerate $\leq 6^{\circ}\text{C}$	6h	48h
TSS	P, G	200	G, C	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 d
pH	P, G	50	G	Analyze immediately	0.25h	0.25 h
NH3-N	P, G	500	G, C	Analyze as soon as possible or add $\text{H}_2\text{SO}_4$ to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	7 d	28 d
TRC	P, G	500	G	Analyze immediately	0.25h	0.25 h
DO (electrode)	G, BOD Bottle	300	G	Analyze immediately	0.25h	0.25 h
Temperature	P, G	--	G	Analyze immediately	0.25h	0.25 h
Metals, general	P, G	1000	G, C	For dissolved filter immediately and add $\text{HNO}_3$ to pH <2	6 months	6 months
Purgeables by purge and trap	G (PTFE lined lid)	40 (X2)	G	HCl to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	7 d	14 d
Base/Neutrals and acids	G (solvent rinsed or baked)	1000	G, C	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 days until extraction 40 days after extraction
Pesticides	G (PTFE lined lid)	1000	C	Refrigerate $\leq 6^{\circ}\text{C}$	7 d	7 days until extraction 40 days after extraction
Fecal Coliform / E-Coli	G, P (Sterilized)	100	G	Refrigerate $\leq 10^{\circ}\text{C}$ If chlorine present, add sodium thiosulfate tablet	6 hrs transport. Start analysis within 2 hrs of receipt in lab.	
Oil and Grease	G	1000	G	HCl or $\text{H}_2\text{SO}_4$ to pH <2, Refrigerate $\leq 6^{\circ}\text{C}$	28 d	28 d

## General Lab Criteria

Approved Standard Methods	
CBOD / BOD 5 Day	Std Methods 5210-B
Ammonia, Selective Electrode Method	Std Methods 4500-NH3 D
Total Residual Chlorine, DPD Colorimetric Method	Std Methods 4500-Cl G
Total Suspended Solids, Dried at 103-105°C	Std Methods 2540-D
Dissolved Oxygen, Membrane Electrode Method	Std Methods 4500-O G
pH, Electrometric Method	Std Methods 4500-H+ B
Fecal Coliform, Membrane Filter Procedure	Std Methods 9222D
Escherichia Coli, Enzyme Substrate Test	Std Method 9223B
Escherichia Coli Membrane Filtration Procedure	EPA Method 1603
Oil and Grease	USEPA 1664A or Std Methods 5520B
Metals, general	USEPA 200, Std Methods 3111B or C, or 3120B
Volatiles (Purgeables by purge and trap)	USEPA 6210, Std Methods 624
Semi-Volatiles (Base/Neutrals and acids)	USEPA 6410; Std Methods 625
Pesticides	USEPA 6410 and 6630, Std Methods 608