



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 23, 2010

Re: Belmont County
Village of Holloway Water Plant
Ohio EPA Permit #0GW00006*AG
Compliance Evaluation Inspection
Correspondence (PWW)

Mayor and Council
Village of Holloway
P.O. Box 163
Holloway, Ohio 43985

Dear Mayor and Council:

On July 14, 2010, I conducted a compliance evaluation inspection of the wastewater treatment system at the Village of Holloway's Water Treatment Plant (WTP). John Brunner, water plant operator of record, and David Davis, water plant operator, were present during the inspection.

Holloway's WTP wastewater is filter backwash water that is discharged through sand filters to filter out iron and manganese removed from the raw drinking water.

The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of the general NPDES permit number 0GW00006*AG. Wastewater samples were not taken. A copy of the inspection report form is attached.

Based on the inspection and file review, the Holloway WTP was found to be in compliance on the day of the inspection. The following is a summary of my comments:

Holloway is reminded that when the sand filters are cleaned to remove the iron and manganese trapped by the filters, the sand/iron/manganese material must be disposed of at an approved landfill.

No response to this report is necessary at this time. If you have any questions, please call me at your convenience at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

Enclosure

c: John Brunner, Operator of Record
c: AS File

NPDES Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0GW00006*AG	OHGW00019	July 14, 2010	C	S	2

B. FACILITY DATA

Name & Location of Facility Inspected	Entry Time	Permit Effective Date
Holloway Water Treatment Plant Jewell Avenue Holloway, Ohio 43985	10:15 a.m.	February 1, 2007
	Exit Time	Permit Expiration Date
	11:00 a.m.	January 31, 2012

Name(s) & Title(s) of On-Site Representative(s)	Phone Number(s)
John Brunner, Operator of Record David Davis, Plant Operator/Street Commission	(740) 312-3197 (740) 968-4024 Office (740) 968-4516 Home
Name, Address, & Title of Responsible Official	Phone Number
Mayor Sue Talkoski Village of Holloway P.O. Box 152 Holloway, Ohio 43985	

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>NA</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>NA</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u> </u> Other
<u>NA</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated; N/A = Not Applicable)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

- Sludge - any sludge/sand removed from the sand filter must be landfilled.


Abbot Stevenson, Inspector, Ohio EPA, Southeast District Office

7/26/10
Date


Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

7/26/10
Date