



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

June 30, 2008

**Re:** Belmont County  
Barnesville WWTP  
Ohio EPA Permit #0PC00001\*GD  
NPDES Permit #OH0024015  
Correspondence (PWW/Major)

Mayor and Council  
Village of Barnesville  
132 N. Arch Street  
Barnesville, Ohio 43713

Dear Mayor and Council Members:

On May 29, 2008, Ken Mettler, of Ohio EPA's Special Investigation Unit, and I conducted a reconnaissance inspection at the Village of Barnesville's wastewater treatment plant (WWTP). The purpose of the inspection was to follow-up on the condition of the effluent sampler that was out of service on the previous inspection. Dave McMillen, plant operator, represented the village during the inspection. A copy of the inspection report is attached.

The new sampler building has been set up and the sampler is inside. The structure currently has temporary power. Permanent power must be provided. The sampler is operational. However, the temperature in the sampler refrigerator needs to be operated within the range of 38 – 42 degrees F (3-5.5 degrees C). The temperature should be checked every time a sample is taken and a log of the temperature kept on site. Provide a date by which a permanent power supply will be provided. Also, provide verification that the temperature in the refrigerator is adequate.

Please respond to this inspection report, in writing, within 30 days of the date of this letter. If you have any questions, please contact me at (740) 380-5284 at your convenience.

Sincerely,

Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/dh

c: Roger Deal, Village Administrator  
c: Gary Billman, Supt.

# NPDES Compliance Inspection Report

## A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPC00001*GD	OH0024015	May 29, 2008	R	S	1

## B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Barnesville WWTP County Road 122 and Township Road 27 Barnesville, Belmont County, Ohio	2:30 p.m.	July 1, 2003
	Exit Time	Permit Expiration Date
	3:00 p.m.	July 1, 2008

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Dave McMillen, Plant Operator	(740) 425-1681
Name, Address and Title of Responsible Official	Phone Number
Mayor Tom Michelli and Council Members Village of Barnesville 132 Arch Street Barnesville, Ohio 43713	(740) 425-3444


## C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>N</u> Flow Measurement	<u>NA</u> Pretreatment
<u>N</u> Records/Reports	<u>N</u> Laboratory	<u>S</u> Compliance Schedules
<u>U</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>U</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u>    </u> Other
<u>N</u> Collection System		


(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

## D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.

  
Abbot Stevenson, Inspector, Ohio EPA, Southeast District Office

6/30/08  
Date

  
Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

6/30/08  
Date