



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 10, 2010

**Re: Belmont County
Barnesville WWTP
Self-monitoring Report Violations
Ohio EPA Permit #0PC00001*HD
Correspondence (PWW/Major)**

Mayor and Council
Village of Barnesville
132 N. Arch Street
Barnesville, Ohio 43713

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of October through December 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type*	Units	Permit Limit	Reported	Date
October 2009:						
001	Total Suspended Solids	30D Conc	mg/L	20	23.3	10/1/2009
001	Total Suspended Solids	7D Conc	mg/L	30	74	10/22/2009
001	Total Suspended Solids	7D Qty	Kg/day	148	230	10/22/2009

***NOTES:** 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Failure to report violations of the effluent limitations is also a violation of your NPDES permit. Please review Part 3 of the NPDES permit for reporting requirements. To ensure that you properly report violations, I have enclosed a copy of the OEPA 24-hour reporting Fact Sheet and report forms. If you are unclear about the reporting procedure please contact me for more information.

Please inform this office in writing, within ten days of receipt of this notification, as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/mlm

Enclosures

- c: Roger Deal, Village Admin., Village of Barnesville (w/enclosures)
- c: Gary Billman, Plant Supt., Village of Barnesville WWTP (w/enclosures)
- c: AS file