



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 15, 2009

**Re:** Belmont County  
Village of Powhatan Point  
Reconnaissance Inspection  
Ohio EPA Permit No. OPB00033\*ED  
Correspondence (PWW)

Mayor Ryan Lee  
Village of Powhatan Point  
104 Mellott Street  
Powhatan Point, Ohio 43942

Dear Mayor Lee:

On May 6, 2009, I conducted a Reconnaissance Inspection at the village of Powhatan Point's pump station on Water Street. This inspection was in response to wastewater superintendent Paul McCloud's report the day before of sewer system capacity problems and overflows due to heavy rains.

The purpose of the inspection was to see if the bypass was occurring on the day of the inspection. The overflow pipe was submerged. There was no evidence of overflow around the pump station. A copy of the inspection report form is attached.

The village is reminded to submit a follow-up report for the overflows in accordance with part III, item 12 of your current (not draft) NPDES permit. If there are any questions, please contact me at (740) 380-5284.

Sincerely,

Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/dh

Enclosures

c: Paul McCloud, Supt.  
c: Board of Public Affairs, Village of Powhatan Point

**NPDES**  
Compliance Inspection Report

**A. NATIONAL DATA SYSTEM CODING**

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PB00033*ED	OH0027219	May 6, 2009	R	S	1

**B. FACILITY DATA**

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Powhatan Point Wastewater Treatment Plant Riverside Drive Powhatan Point	9:30 a.m.	July 1, 2003
	Exit Time	Permit Expiration Date
	9:45 a.m.	June 30, 2008

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
None	
Name, Address and Title of Responsible Official	Phone Number
Mayor Ryan Lee Village of Powhatan Point 104 Mellott Street Powhatan Point, Ohio 43942	(740) 795-4201

**C. AREAS EVALUATED DURING INSPECTION**

<u>S</u> Permit	<u>N</u> Flow Measurement	<u>N</u> Pretreatment
<u>N</u> Records/Reports	<u>N</u> Laboratory	<u>N</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>N</u> Effluent/Receiving Waters	<u>N</u> Self-Monitoring Program
<u>N</u> Facility Site Review	<u>N</u> Sludge Storage/Disposal	<u>    </u> Other
<u>U</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

**D. SUMMARY OF FINDINGS/COMMENTS** (attach additional sheets if necessary)

- Collection System - has Inflow/Infiltration (I/I) problems. The village has committed to an I/I removal project this summer. The village must continue to look for and eliminate I/I.
- NPDES permit has been drafted and will be issued final before July 1, 2009.

  
Abbot Stevenson, Inspector, Ohio EPA, Southeast District Office

5/15/09  
Date

  
Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

5/15/09  
Date