



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 9, 2010

Re: Belmont County
Village of Powhatan Point
Self-Monitoring Report Violations
Ohio EPA Permit No. OPB00033*ED
Correspondence (PWW)

Mayor and Council
Village of Powhatan Point
104 Mellott Street
Powhatan Point, Ohio 43942

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of July through December 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type*	Units	Permit Limit	Reported	Date
October 2009:						
001	Fecal Coliform	7D Conc	#/100 mL	400	474	10/8/2009
December 2009:						
581	Fecal Coliform in Sludge	1D Conc	MPN/g	200000	2742857	12/1/2009

- NOTES:** 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Conc = Monthly Average Concentration Value
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

- c: Paul McCloud, Plant Operator, Village of Powhatan Point
- c: Board of Public Affairs, Village of Powhatan Point