



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 9, 2010

Re: Belmont County
City of St. Clairsville
Wastewater Treatment Plant (main)
Self-Monitoring Report Violations
Ohio EPA Permit No. OPC00014*ED
Correspondence (PWW)

Mayor Robert Vincenzo and City Council
City of St. Clairsville
100 N. Market Street
P.O. Box 537
St. Clairsville, Ohio 43950

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of July through December 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type	Units	Permit Limit	Reported	Date
October 2009:						
001	Nitrogen, Ammonia	30D Conc	mg/L	1.0	1.13	10/1/2009
001	Nitrogen, Ammonia	7D Conc	mg/L	1.5	2.9	10/15/2009

- Notes:**
- 1D Conc = Daily Average Concentration Value
 - 1D Qty = Daily Average Loading Value
 - 7D Conc = Weekly Average Concentration Value
 - 30D Conc = Monthly Average Concentration Value
 - 7D Qty = Weekly Average Loading Value
 - 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,

A handwritten signature in black ink, appearing to read 'Abbot Stevenson', with a long horizontal flourish extending to the right.

Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

c: Josh Goodrich, Supt.