



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

May 29, 2007

Re: Belmont County
Village of Shadyside WWTP
Self-monitoring Report Violations
Ohio EPA Permit No. OPC00014*ED
NPDES Permit No. OH0027294
Correspondence (PWW)

Board of Public Affairs
Village of Shadyside
50 East 39th Street
Shadyside, Ohio 43947

Dear Board Members:

We have received your self-monitoring reports covering the months of January 2006 through April 2007 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Permit Limit	Reported	Date
January 2007:					
001	Fecal Coliform	7D Conc	2000	3823	1/15/07
March 2007:					
001	Total Suspended Solids	7D Qty	103	160	3/15/07

- NOTES:** 1D Conc = Daily Maximum Concentration Value
 1D Qty = Daily Maximum Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Also, on March 15, 2007, as required by the NPDES permit, the operator reported a Sanitary Sewer Overflow (SSO) from the manhole at the head of the wastewater treatment plant. This discharge of untreated sewage is a violation of Ohio Revised Code Chapter 6111 and the NPDES permit.

Be reminded that failure to report violations of the effluent limitations is also a violation of your NPDES permit. Please review Part 3 of the NPDES permit for reporting requirements.

The operator is reminded that failure to report is a violation of the operator certification rules, OAC 3745-07-09.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

Enclosure

c: Doug Beekman, Superintendent