



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 5, 2010

**Re: Gallia County
Gallipolis Hospitality WWTP
Notice of Violation SNC
Permit OPR00049*GD
Correspondence (PWW)**

Gallipolis Hospitality
577 State Route 7
Gallipolis, Ohio 45631

Dear Facilities Manager:

We have received your self-monitoring report covering the months of July through December 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2009	001	31616	Fecal Coliform	30D Conc	200	6700.	8/1/2009
August 2009	001	31616	Fecal Coliform	7D Conc	400	6700.	8/15/2009
September 2009	001	31616	Fecal Coliform	30D Conc	200	570.	9/1/2009
September 2009	001	80082	CBOD 5 day	30D Conc	25	26.5	9/1/2009
September 2009	001	31616	Fecal Coliform	7D Conc	400	570.	9/15/2009
October 2009	001	31616	Fecal Coliform	30D Conc	200	210.	10/1/2009

In addition, sludge weight was not reported in December for station 588.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If you have not already done so, please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5218.

Sincerely,



Dan Messerly
District Representative
Permits and Enforcement Section
Division of Surface Water

DM/dh

c: Dave Carpenter, Operator