



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 12, 2007

Re: Guernsey County
Buckeye Trail Schools
Compliance Inspection
Correspondence (PWW)

Mr. Lonnie Caudill, Principal
Buckeye Trail Middle School
65555 Wintergreen Road
Lore City, Ohio 43755

Dear Mr. Caudill:

On March 8, 2007, I conducted a Compliance Evaluation Inspection (CEI) of the Buckeye Trail Junior/Senior High School's wastewater treatment facility. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES Permit Number OPT00012*AD.

As a result of my inspection, the following observations were made.

1. At the time of my inspection the southeastern portion of the aeration basin was found to be stagnant near the surface and a thin layer of scum was present. The diffusers in each aeration basin should be checked and adjusted to the proper levels to provide adequate roll and complete mixing within each basin.
2. Upon thawing the idle filter bed should be cleaned of any accumulated solids and placed into service to allow for cleaning of the current bed in use. Solids should be appropriately disposed of in a sanitary waste landfill.

According to the compliance schedule in your permit, the new total residual chlorine limit of .019 mg/l will be effective on May 1, 2008. A PTI for the installation of a de-chlorination system was recently approved and actions should be taken to complete the installation by May 1, 2008.

At the time of my inspection, the facility appeared to be in substantial compliance to the terms and conditions of your NPDES permit. Enclosed is a copy of my detailed inspection report.

If you have any questions please call me at (740) 380-5416.

Sincerely,

A handwritten signature in black ink that reads "Jake Greuey". The signature is written in a cursive style with a large initial "J".

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

Enclosure

c: Paul Fields, Operator

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPT00012*AD	0H0094439	March 8, 2007	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Buckeye Trail Jr. & Sr. High Schools WWTP State Route 285 Old Washington, Ohio	9:45 a.m.	May 1, 2005
	Exit Time	Permit Expiration Date
	10:30 a.m.	April 30, 2010

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Lonnie Caudill, Principal	
Name, Address and Title of Responsible Official	Phone Number
Lonnie Caudill, Principal Buckeye Trail Middle School 65555 Wintergreen Road Lore City, Ohio 43755	


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>N</u> Flow Measurement	<u>--</u> Pretreatment
<u>S</u> Records/Reports	<u>--</u> Laboratory	<u>S</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>--</u> Sludge Storage/Disposal	<u>---</u> Other
<u>--</u> Collection System		


(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.


 Jake Greuey, Inspector, Ohio EPA, Southeast District Office

3/12/07
 Date


 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

3/12/07
 Date