



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6480
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 26, 2007

Re: Guernsey County
Go Mart #57 WWTP
Compliance Inspection
Correspondence (PWW)

Mr. Mike Conant
Go Mart, Inc.
64322 Wintergreen Road
Lore City, Ohio 43755

Dear Mr. Conant:

On October 11, 2007, I conducted a Compliance Evaluation Inspection (CEI) of the Go Mart #57 wastewater treatment facility. The purpose of the inspection was to determine compliance with the terms and conditions of National Pollutant Discharge Elimination System (NPDES) permit number OPR00089*AD. Mr. Matt Stiers, plant operator was present at the time of my inspection.

As a result of my inspection, the following observations were made:

1. The new equalization tank has been installed and appears to be improving treatment within the plant as less bulking sludge was observed as well as surface scum in the clarifier. Continued monitoring of alkalinity and ammonia levels in the aeration basin should continue to determine the proper timer settings for the blowers.
2. The wastewater flow should be switched to the clean filter bed and the other bed dried to permit the removal and proper disposal of the solids.

Enclosed is a copy of my detailed inspection report. If you have any questions please call me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

Enclosure

c: Matt Stiers, Operator

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPR00089*AD	OH0099759	October 11, 2007	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Go Mart #57 WWTP S.R. 285/ I-70 Old Washington, Ohio	1:30 p.m.	July 1, 2004
	Exit Time	Permit Expiration Date
	2:00 p.m.	June 30, 2009

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Matt Stiers, Operator	(740) 584-1611
Name, Address and Title of Responsible Official	Phone Number
Mike Conant Go Mart, Inc. 64322 Wintergreen Road Lore City, Ohio 43755	

C. AREAS EVALUATED DURING INSPECTION

<input checked="" type="checkbox"/> Permit	<input type="checkbox"/> Flow Measurement	<input type="checkbox"/> Pretreatment
<input checked="" type="checkbox"/> Records/Reports	<input type="checkbox"/> Laboratory	<input checked="" type="checkbox"/> Compliance Schedules
<input checked="" type="checkbox"/> Operations & Maintenance	<input checked="" type="checkbox"/> Effluent/Receiving Waters	<input checked="" type="checkbox"/> Self-Monitoring Program
<input checked="" type="checkbox"/> Facility Site Review	<input checked="" type="checkbox"/> Sludge Storage/Disposal	<input type="checkbox"/> Other
<input type="checkbox"/> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.



 Jake Greuby, Inspector, Ohio EPA, Southeast District Office

10/29/07

 Date



 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

10/29/07

 Date