



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 14, 2008

Re: Guernsey County
ODOT Rest Area Inspections
Rest Areas 05-27, 05-29, 05-30
Correspondence (PWW)

Mr. Terry Gregg, Operator
ODOT, District 5
P.O. Box 306
Jacksontown, Ohio 43030

Dear Mr. Gregg:

On October 7, 2008, I conducted compliance evaluation inspections of the three ODOT rest area's wastewater treatment plants located in Guernsey County. The purpose of the inspections were to determine compliance with the terms and conditions of the National Pollutant Discharge Elimination System (NPDES) permits for each facility. The inspections at each facility were conducted in your presence and the findings of the three inspections are summarized below.

At the time of my inspections all treatment units at the three rest stops were found to be operable and well maintained. During my inspections, the surface of the settling tanks consisted of clear water with very little surface scum and clean weirs. The filter beds at all three sites were found to be clean with no weed growth or accumulation of solids although they are becoming deficient in sand. According to you, efforts are being made to replenish each bed with adequate sand to maintain the 18" required sand depth. Attached is a copy of our filter sand specifications as well as some suppliers.

The effluent from all three sites was found to be clear and free of any objectionable odors. Copies of my detailed inspection reports for all three sites are enclosed. If you have any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Site Representative
Division of Surface Water

JJG/dh

Enclosures

**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PP00058*ED	OH0076929	July 11, 2007	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
ODOT Rest Area 05-30 Interstate 77 South 37.1 Milemarker Buffalo, Ohio	1:25 p.m.	February 1, 2007
	Exit Time	Permit Expiration Date
	2:00 p.m.	January 31, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Terry Gregg, Operator	(740) 404-7810
Name, Address and Title of Responsible Official	Phone Number
Terry Gregg, Operator ODOT, District 5 P.O. Box 306 Jacksontown, Ohio 43030	

C. AREAS EVALUATED DURING INSPECTION

- | | | |
|--------------------------------------|---------------------------------------|-------------------------------------|
| <u> </u> S Permit | <u> </u> -- Flow Measurement | <u> </u> -- Pretreatment |
| <u> </u> S Records/Reports | <u> </u> * Laboratory | <u> </u> -- Compliance Schedules |
| <u> </u> S Operations & Maintenance | <u> </u> S Effluent/Receiving Waters | <u> </u> S Self-Monitoring Program |
| <u> </u> S Facility Site Review | <u> </u> S Sludge Storage/Disposal | <u> </u> Other |
| <u> </u> -- Collection System | | |


(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

* Contract laboratory used and not evaluated.
See attached letter.




Jake Greuey, Inspector, Ohio EPA, Southeast District Office



Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office



Date