



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 19, 2010

**Re: Guernsey County
Pike Elementary School
Compliance Evaluation Inspection
Correspondence (PWW)**

Mr. Jim Heagen, Superintendent
East Muskingum Schools
3505 John Glenn School Road
New Concord, Ohio 43762-9702

Dear Mr. Heagen:

On March 12, 2010, I conducted a compliance evaluation inspection (CEI) of the Pike Elementary School's wastewater treatment plant. The purpose of the inspection was to determine compliance with the terms and conditions of National Pollutant Discharge Elimination System (NPDES) permit number 0PT00016*AD. Custodian, Mark McManaway was present during my inspection.

At the time of my inspection, all components of the treatment system were fully operational. Inspection of the clarifier showed minimal surface scum and a moderate buildup of algae on the weir. Cleaning of the weir should be done on a routine basis to prevent algae and solids buildup which could wash out into the sand filters.

At the time of my inspection, the effluent was clear with very little suspended solids and no objectionable odor. Attached is a copy of my detailed inspection report. If you have any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JGG/dh

Enclosure

c: Dale Mallet, Operator

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPT00016*AD	OH0094889	March 12, 2010	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Pike Elementary School WWTP 4533 Peters Creek Rd. New Concord, Ohio	11:00 a.m.	April 1, 2005
	Exit Time	Permit Expiration Date
	11:20 a.m.	March 31, 2010

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Mark McManaway, Custodian	
Name, Address and Title of Responsible Official	Phone Number
Mr. Jim Heagen, Superintendent East Muskingum Schools 3505 John Glenn School Road New Concord, Ohio 43762-9702	

C. AREAS EVALUATED DURING INSPECTION

<u> </u> S Permit	<u> </u> S Flow Measurement	<u> </u> -- Pretreatment
<u> </u> S Records/Reports	<u> </u> * Laboratory	<u> </u> S Compliance Schedules
<u> </u> S Operations & Maintenance	<u> </u> S Effluent/Receiving Waters	<u> </u> S Self-Monitoring Program
<u> </u> S Facility Site Review	<u> </u> -- Sludge Storage/Disposal	<u> </u> Other
<u> </u> -- Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.


* Laboratory analysis is conducted by a contract lab which was not evaluated.



Jake Greuby, Inspector, Ohio EPA, Southeast District Office

3/19/10

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

3/19/10

Date