



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 24, 2009

Re: Guernsey County
Senecaville WWTP
Compliance Inspection
Correspondence (PWW)

Mayor and Council
Village of Senecaville
P.O. Box 5
Senecaville, Ohio 43780

Dear Mayor and Council:

On March 11, 2009, I conducted a Compliance Evaluation Inspection (CEI) at the Senecaville wastewater treatment plant. The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of NPDES Permit Number OPA00089*CD. Plant Operator Matt Stiers was present during the inspection.

Inspection of the two aerated lagoons and the one facultative lagoon showed the water to contain a slight green discoloration and a minimal odor. At the time of my inspection, the newly installed flow meter has yet to be calibrated and placed into operation. All efforts shall be made to properly calibrate the flow meter and begin reporting representative flow numbers by May 1, 2009. Please provide a written verification within 14 days upon receipt of this letter as to when the flow meter will be calibrated. Attached is a copy of my inspection report.

If you have any questions about my inspection or terms of your permit, please call me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

Enclosure

c: Matt, Stiers, Operator

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PA00089*CD	OH0041548	March 11, 2009	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Senecaville WWTP State Rotue 313 Senecaville, Ohio	9:40 a.m.	March 1, 2004
	Exit Time	Permit Expiration Date
	10:00 a.m.	February 28, 2009

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Matt Stiers, Operator	(740) 685-6776
Name, Address and Title of Responsible Official	Phone Number
Mayor and Council Village of Senecaville P.O. Box 5 Senecaville, Ohio 43780	


C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>M</u> Flow Measurement	<u>--</u> Pretreatment
<u>S</u> Records/Reports	<u>*</u> Laboratory	<u>--</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>--</u> Sludge Storage/Disposal	<u> </u> Other
<u>N</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


*Contract laboratory used and not evaluated.
See attached letter.



Jake Greuey, Inspector, Ohio EPA, Southeast District Office

3/23/09

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

3/23/09

Date