



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 17, 2009

Re: Guernsey County
Spring Valley Campground
Compliance Evaluation Inspection
Correspondence (PWW)

Mr. Dan Edmunds
Spring Valley Campground
8000 Dozer Road
Cambridge, Ohio 43725

Dear Mr. Edmunds:

On July 14, 2009, I conducted a compliance evaluation inspection (CEI) at the Spring Valley Campground's wastewater treatment plant. The purpose of the inspection was to determine compliance with the terms and conditions of National Pollutant Discharge Elimination System (NPDES) permit number OPR00143*BD. Mr. Jim Duty, plant operator and you were present at the time of my inspection.


Based on the findings of my inspection and the review of our records, I have the following comments:

1. Inspection of the aeration tank and clarifier showed all treatment units to be well maintained and providing effective treatment.
2. The ozonator was found to be in operation and the effluent was observed relatively clear and free of any objectionable odors.
3. The sand filter beds were found to be well maintained and free of any accumulated solids.

Review of the Discharge Monitoring Reports (DMRs) from January through April revealed no effluent violations with only one fecal coliform violation in May. An

explanation for this violation was received and the disinfection system appeared to be operating properly. Attached is a copy of my detailed inspection report. If you have any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JGG/dh

Enclosure

c: Jim Duty, Operator

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPR00143*BD	OH0127990	July 14, 2009	C	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Spring Valley Campground WWTP 8000 Dozer Road Cambridge, Ohio	2:00 p.m.	April 1, 2007
	Exit Time	Permit Expiration Date
	2:55 p.m.	March 31, 2012

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Jim Duty, Operator	(740) 525-8060
Name, Address and Title of Responsible Official	Phone Number
Dan Edmunds, Owner 8000 Dozer Road Cambridge, Ohio 43725	


C. AREAS EVALUATED DURING INSPECTION

- | | | |
|-----------------------------------|------------------------------------|----------------------------------|
| <u>S</u> Permit | <u>S</u> Flow Measurement | -- Pretreatment |
| <u>S</u> Records/Reports | * Laboratory | -- Compliance Schedules |
| <u>S</u> Operations & Maintenance | <u>S</u> Effluent/Receiving Waters | <u>S</u> Self-Monitoring Program |
| <u>S</u> Facility Site Review | -- Sludge Storage/Disposal | Other |
| <u>S</u> Collection System | | |

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

* Contract Laboratory used and not evaluated.
See attached letter.



Jake Greuey, Inspector, Ohio EPA, Southeast District Office

7/16/09

Date



Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

7/17/09

Date