



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 24, 2007

Re: Guernsey County
Byesville Water Treatment Plant
Compliance Evaluation Inspection
Correspondence (IWW)

Mayor and Council
221 East Main Street
P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

On July 11, 2007, I conducted a compliance evaluation inspection (CEI) of the Byesville water treatment plant. The purpose of the inspection was to determine compliance with the terms and conditions of National Pollutant Discharge Elimination System (NPDES) permit number 01Y00100*AD. This inspection was also conducted as a pre-permit inspection since the current discharge permit expires on December 31, 2007. Mr. Thomas McVickers, plant superintendent was present at the time of my inspection.

Based on the findings of my inspection and the review of our records, I have the following comments:

1. According to Mr. McVickers a concrete collection trough was installed at the end of each sediment basin which drains sludge to the concrete tanks for removal. The installation of the troughs and tanks has enabled the city to concentrate sludge in the tanks which can then be decanted prior to pumping and hauling to the Zanesville WWTP for further treatment and final disposal in a landfill.
2. The two sand filter beds were relatively clean with minimal solids on the surface of the two beds. The two beds should be leveled to encourage use of the entire bed.

At the time of my inspection, the effluent was clear and colorless with very little suspended solids. Attached is a copy of my detailed inspection report. If you have any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JGG/dh

Enclosure

c: Thomas McVickers, Superintendent, Byesville WTP

NPDES Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0IY00100*AD	OH0128112	July 11, 2007	C	S	2

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Byesville WTP Conquer Hill Road Byesville, Ohio 43723	8:30 a.m.	January 2, 2003
	Exit Time	Permit Expiration Date
	9:30 a.m.	December 31, 2007

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Thomas McVickers, Plant Superintendent	
Name, Address and Title of Responsible Official	Phone Number
Mayor and Council 221 East Main Street PO Box 8 Byesville, Ohio 43723	

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>--</u> Pretreatment
<u>S</u> Records/Reports	<u>--</u> Laboratory	<u>--</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u>---</u> Other
<u>--</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

See attached letter.



 Jake Greuy, Inspector, Ohio EPA, Southeast District Office

7/23/07

 Date



 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

7/25/07

 Date