



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 8, 2009

**Re: Guernsey County
BP Bulk Plant - Cambridge
Compliance Evaluation Inspection
Correspondence (IWW)**

Mr. Frank Marsek
BP Oil Company
4850 East 49th Street
Cuyahoga Heights, Ohio 44125

Dear Mr. Marsek:

On September 22, 2009, I conducted a compliance evaluation inspection (CEI) at the Caldwell BP Bulk Plant facility operated by Mr. Richard Rutherford. The purpose of the inspection was to determine your compliance status with the terms and conditions of National Pollutant Discharge Elimination System (NPDES) permit number 01N00219*CD.

Based on the findings of my inspection and the review of our records, I have the following comments:

1. At the time of my inspection, the dike containment area was structurally sound and the small lined detention pond receiving discharge from the oil water separator was clean with no visible sheen. During my inspection, the water level in the pond was low and no discharge was observed.
2. The loading rack area was found relatively clean with only a small oil stained area near the catch basin which drains to the oil water separator. Physical observation of the immediate area near the loading dock was found to be appropriately graded to prevent entry of additional surface runoff into the catch basin.

Attached is a copy of my detailed inspection report. If you have any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JGG/dh

Enclosure

c: Richard Rutherford, Business Owner, Cambridge BP

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No. 01N00219*CD	NPDES No. OH0120847	Date September 22, 2009	Inspection Type C	Inspector S	Facility Type 2
----------------------------------	-------------------------------	-----------------------------------	-----------------------------	-----------------------	---------------------------

B. FACILITY DATA

Name and Location of Facility Inspected BP Oil Bulk Plant 329 N. Second Street Cambridge, Ohio 43725	Entry Time 9:15 a.m.	Permit Effective Date May 1, 2007
	Exit Time 9:45 a.m.	Permit Expiration Date April 30, 2012

Name(s) and Title(s) of On-Site Representative(s) Richard Rutherford, Operator	Phone Number(s) (740) 432-2159
Name, Address and Title of Responsible Official Frank Marsek, HSE Coordinator BP Products North America, Inc. 4850 E. 49 th Street MBC3-103D Cuyahoga, Heights, Ohio 44125	Phone Number (216) 271-8055

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>N</u> Flow Measurement	<u>S</u> Pretreatment
<u>S</u> Records/Reports	<u>*</u> Laboratory	<u>--</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>--</u> Sludge Storage/Disposal	<u>---</u> Other
<u>--</u> Collection System		

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS(attach additional sheets if necessary)

* Contract laboratory used and not evaluated.

Jake Greuy
Jake Greuy, Inspector, Ohio EPA, Southeast District Office

10/2/09
Date

Timothy M. Campbell
Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

10/8/09
Date