



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 19, 2008

Re: Guernsey County
Seneca Lake Campground
Self-Monitoring Report Violations
NPDES Permit #OPX00002*AD
Correspondence (PWW)

Mr. Boris Slogar, Chief Engineer
Muskingum Watershed Conservancy District
1319 Third Street
New Philadelphia, Ohio 44663

Dear Mr. Slogar:

We have received your self-monitoring reports covering the months of April through May 2008 for the Seneca Lake Lagoon wastewater facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	13.	4/1/2008
001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.298	4/1/2008
001	00665	Phosphorus, Total (P)	30D Qty	0.14	.29661	4/1/2008
001	0530	Total Suspended Solids	1D Qty	2.52	3.74715	4/8/2008
001	00530	Total Suspended Solids	1D Conc	18	24.	4/15/2008
001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.54	4/15/2008
001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.9	4/21/2008
001	00665	Phosphorus, Total (P)	1D Qty	0.21	.57078	4/21/2008
001	00665	Phosphorus, Total (P)	1D Conc	1.5	4.13	4/28/2008
001	00665	Phosphorus, Total (P)	1D Qty	0.21	.42207	4/28/2008
May 2008:						
001	50060	Chlorine, Total Residual	1D Conc	0.011	.11	5/1/2008
001	00665	Phosphorus, Total (P)	30D Conc	1.0	3.54	5/1/2008
001	00665	Phosphorus, Total (P)	30D Qty	0.14	.37477	5/1/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.14	5/2/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.11	5/3/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.09	5/4/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.1	5/5/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.12	5/6/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.57	5/7/2008
001	00665	Phosphorus, Total (P)	1D Conc	1.5	3.54	5/7/2008
001	00665	Phosphorus, Total (P)	1D Qty	0.21	.52256	5/7/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.44	5/8/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.29	5/9/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.17	5/10/2008

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	80082	CBOD 5 day	1D Conc	15	16.	5/12/2008
001	00665	Phosphorus, Total (P)	1D Conc	1.5	5.02	5/12/2008
001	00665	Phosphorus, Total (P)	1D Qty	0.21	.39901	5/12/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.26	5/14/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.4	5/15/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.36	5/16/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.25	5/17/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.15	5/18/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.16	5/19/2008
001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.06	5/19/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.17	5/20/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.13	5/21/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.53	5/22/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.47	5/23/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.38	5/24/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.24	5/25/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.27	5/26/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.55	5/27/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.44	5/29/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.26	5/30/2008
001	50060	Chlorine, Total Residual	1D Conc	0.011	.46	5/31/2008

*1 D Conc is equal to the maximum daily concentration limit.
 1 D Qty is equal to the maximum daily loading limit.
 7D Conc is equal to the average weekly concentration limit.
 7D Qty is equal to the average weekly loading limit.
 30D Conc is equal to the average monthly concentration limit.
 30D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111. Upon review of your discharge monitoring reports (DMRs) it was also noted that no monitoring reports were received for the months of June and July. Please submit the appropriate DMR forms to our Columbus office and provide a written explanation within **10** days upon receipt of this letter to the above violations and efforts to be taken to prevent further occurrences. These frequent limit violations have placed your facility on our significant non-compliance list, which subject you to enforcement action.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
 District Representative
 Division of Surface Water

JJG/dh